


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County Kiowa Fraction SE 1/4 SE 1/4 NE 1/4 Section number 25 Township number T 27 S R 16 E/W Range number	
2. Distance and direction from nearest town or city: SE 3/4 Haviland Kansas	
3. Owner of well: Richard Rose R.R. or street: Haviland Kans City, state, zip code:	
4. Locate with "X" in section below: Sketch map: 	
6. Bore hole dia. 8 3/4 in. Completion date 7-28-76 Well depth _____ ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material RMP Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight 200 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200	
5. Type and color of material	
	From To
Top Sand	0 2
Sandy Clay	2 17
HARD Pan	17 19
COURSE Sand	19 24
HARD Clay	24 27
SAND & GRAVEL	27 65
Clay	65 76
GRAVEL	76 79
Clay	79 80
GRAVEL	80 100
10. Screen: Manufacturer's name Sumplower Plastics Type RMP Dia. _____ Slot/spacing 1/8 Length 20 Set between 88 ft. and 100 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 x 1/4	
11. Static water level: _____ mo./day/yr. 48 ft. below land surface Date _____	
12. Pumping level below land surfaces: 48 ft. after 1 hrs. pumping 5 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.	
13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.	
16. Nearest source of possible contamination: _____ ft. 200 Direction NW Type Hogs Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: _____ Not installed Manufacturer's name Finky Walling Model number 1030 15 HP Volts 230 Length of drop pipe 84 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation:	19. Remarks:
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Hays Water Well Sign. 2-28-76 Business name _____ License No. _____ Address 603 S Maple Greensboro Signed Carl Hays Date 2-28-76 Authorized representative

T 27
 S R 16
 Sec 25
 SE 1/4
 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5