USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Kiowa	SE C 1/4 1/4 1/4	20	T 27 S	R 17 E/W

2. Distance and direction from nearest town or city: Brunswig, Ks.
Street address of well location if in city: 4 1/2 - 5 E. of Brunswig

3. Owner of well: Ron Ashworth
R.R. or street: Rt. 2
City, state, zip code: Larned, Ks

4. Locate with "X" in section below: Sketch map:

N — NW | NE — W | E — SW | SE (X) — S — 1 Mile

6. Bore hole dia. 24 in. Completion date _____
Well depth 140 ft. 2-21-75

7. __ Cable tool ✓ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
✓ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material steel ✓ Height: (Above) or ~~below~~
Threaded ____ Welded ✓ Surface 18 in.
RMP ____ PVC ____ Weight ____ lbs./ft.
Dia. 16 in. to 140 ft. depth Wall Thickness: inches or
Dia. ____ in. to ____ ft. depth gage No. 7

5. Type and color of material	From	To
Sandy Top Soil	0	2
Sandy Brown Clay & Fine Sand	2	18
Yellow Brown Clay	18	20
Brown Clay	20	26
Sand & Gravel Clean Coarse loose	26	43
Yellow Brown Clay	43	45
Sand & Gravel Clean Coarse loose	45	100
Brown Clay	100	116
Sand & Gravel Clean Coarse loose	116	139
Brown & Yellow Brown Clay	139	146

(Use a second sheet if needed)

10. Screen: Manufacturer's name Doerrs
Type steel Dia. 16
Slot ~~gauze~~ 3/16 Length 60
Set between 80 ft. and 140 ft.
____ ft. and ____ ft.
Gravel pack? ✓ Size range of material 1/2 3/4 3/8

11. Static water level: mo./day/yr.
30 ft. below land surface Date 1-3-75

12. Pumping level below land surfaces:
30 ft. after 2 hrs. pumping 1400 g.p.m.
____ ft. after ____ hrs. pumping ____ g.p.m.
Estimated maximum yield 1600+ g.p.m.

13. Water sample submitted: mo./day/yr.
✓ Yes ____ No Date 1-8-75

14. Well head completion:
____ Pitless adapter ____ Inches above grade

15. Well grouted? ✓
With: ____ Neat cement ____ Bentonite ✓ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 2 mi Direction W Type feedlot
Well disinfected upon completion? ____ Yes ____ No

17. Pump: ____ Not installed
Manufacturer's name ~~Amarillo~~ WHR
Model number 2-12MA HP 80 Volts ____
Length of drop pipe 70 ft. capacity 700 g.p.m.
Type:
____ Submersible ✓ Turbine
____ Jet ____ Reciprocating
____ Centrifugal ____ Other

18. Elevation:
Topography:
____ Hill
____ Slope
____ Upland
____ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Rosencrantz-Bemis 134
Business name License No.
Address Great Bend, Ks
Signed Fredia Hudson Date 9/11
Authorized representative

T 27 R 17 E/W Sec 20 1/4 1/4 1/4 CSE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023