

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County KIOWA	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 24	Township number T 27	Range number S R 17W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: XPLOR drilling Co. R.R. or street: City, state, zip code: Wichita, Ks			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date <u>1 MAR 78</u> Well depth <u>80</u> ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface <u>12</u> in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>60</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. <u>258</u>		
Sandy fine Sand, fine		0	2	10. Screen: Manufacturer's name _____ Type <u>Sawtooth</u> Dia. <u>3</u> Slot/gauze <u>3/8</u> Length <u>20'</u> Set between <u>60</u> ft. and <u>80</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8 X 1/4</u>		
Clay, sandy		2	12	11. Static water level: _____ mo./day/yr. <u>21</u> ft. below land surface Date <u>1 MAR 78</u>		
Clay, green		12	28	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>50</u> g.p.m.		
Sand, fine to coarse and med. gravel, some clay		28	57	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Sand, coarse and gravel		57	89	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
Clay, tan		89	94	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Sand, fine to coarse and coarse gravel		94	105	16. Nearest source of possible contamination: ft. _____ Direction _____ Type <u>ADAMS</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump Svc. License No. <u>325</u> Business name Address <u>121 S. Taylor Pratt, Ks.</u> Signed <u>[Signature]</u> Date <u>2 Aug 78</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 27 R 17W Sec 24 NE NE NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5