

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Kiowa Garld T		Fraction SW 1/4 SW 1/4 <i>W</i>	Section number 28	Township number T 27	Range number S R 17
2. Distance and direction from nearest town or city: Street address of well location if in city: Haviland 5W 3N			3. Owner of well: Garld Tuttle R.R. or street: City, state, zip code: Haviland, Ks.		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 8 in. Completion date 4-18 Well depth 80 ft.	
5. Type and color of material		From		To	
		Soil fine sand		0	31
		clay		31	39
		medium sand		59	80
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casings: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 22 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258	
				10. Screen: Manufacturer's name _____ Pumpco Type PVC Dia. 5 Slot/gauge 0.30 Length 10 Set between 70 ft. and 80 ft. _____ ft. and _____ ft. Gravel pack? <input type="checkbox"/> Size range of material 1/8 in	
				11. Static water level: _____ mo./day/yr. 50 ft. below land surface Date 6-27-78	
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.	
				16. Nearest source of possible contamination: <input checked="" type="checkbox"/> ft. 100 Direction W Type 100 Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts 230 Length of drop pipe 83 ft. capacity _____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. James Hoos 146 Business name License No. Address _____ Signed W H [Signature] Date 6-18-78 Authorized representative	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: customer to pour slab			

T 27
 R 17
 S R 17
 Sec 28
 SW 1/4
 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5