

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction 1/4 SW 1/4 SW 1/4	Section number 5	Township number T 27 S R 18 E W	Range number 18 E W
2. Distance and direction from nearest town or city: 8 1/2 Northwest of Greensburg, KS Street address of well location if in city:				3. Owner of well: Allan F. Robb XXXXXXXXXX Le Grand Pin, Parc Cezanne, Route du XXXXXXXXXX Tholonet, 13100 Aix-en-Provence, FRANCE		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 10-28-75 Well depth 70 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	3	9. Casing: Material Styrene Weight: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 1.5 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200#		
Brown clay		3	12	10. Screen: Manufacturer's name Jess & Lowell Type Styrene 200 Dia. 5" <input checked="" type="checkbox"/> Slot gauze 1/8 Length 10' Set between 38 60 ft. and 70 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 3/8-200#		
Sand & gravel		12	22	11. Static water level: _____ mo./day/yr. 30 1/2 ft. below land surface Date 10-28-75		
Brown & yellow clay & gravel streaks		22	57	12. Pumping level below land surfaces: N/C ____ ft. after _____ hrs. pumping _____ g.p.m. ____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Sand & gravel		57	70	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address Great Bend, KS Signed <i>Olw Clarke</i> Date 10-28-75 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

27 18 W
 T R E
 Sec 5 SW SW SW SW
 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5