


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction 1/4 C 1/4 SE 1/4	Section number 7	Township number T 27 S R 18 E/W	Range number 18
2. Distance and direction from nearest town or city: South of Hinsley, KS on 183 to Co. Line Street address of well location if in city: 1 3/4 mi So 1/4 mi west			3. Owner of well: Dallas Hart R.R. or street: 5105 East 21st St. City, state, zip code: Wichita, KS, 67202			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 2 3/4 in. Completion date _____ Well depth 168 ft. 6-14-77			
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Sandy top soil			0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay			2	13	9. Casing: Material Steel Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 18 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 1 1/2 in. to 1 1/2 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 7	
Sand & gravel			13	25	10. Screen: Manufacturer's name _____ Type Steel Dia. _____ Slot/auge 3/16 Length 60 Set between 88 ft. and 168 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 to 3/8	
Sandy clay			25	30	11. Static water level: _____ mo./day/yr. 38 ft. below land surface Date 3-18-77	
Sand & gravel clay mix			30	41	12. Pumping level below land surfaces: 43 ft. after 1 hrs. pumping 600 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1400 g.p.m.	
Sand & gravel			41	82	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 3-18-77	
Sand & gravel little clay mix			82	86	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
Sand & gravel			86	108	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Clay			108	130	16. Nearest source of possible contamination: ft. 500 Direction North Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Sand & gravel			130	170	17. Pump: _____ Not installed Manufacturer's name Layne Bowler Model number 610AH HP 60 Volts _____ Length of drop pipe 100 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay			170	178	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz-Bemis 134 Business name License No. Address Great Bend, KS 67530 Signed Sandy Kilgore Date _____ Authorized representative	
Shale			178	180		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 27 S R 18 E
 Sec 7
 1/4 1/4 1/4 1/4
 CSE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5