


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kiowa	Fraction 1/4 c 1/4 ne 1/4	Section number 21	Township number T 27 S	Range number R 18 E <u>W</u>
2. Distance and direction from nearest town or city: from Centerview 8-S 1 1/2-W 1/4-S 1320'-E into field			3. Owner of well: Dick Rich R.R. or street: none City, state, zip code: Greensburg, Ks. 67054		
4. Locate with "X" in section below: N  W E S 1 Mile			6. Bore hole dia. <u>29</u> in. Completion date _____ Well depth <u>153</u> ft. <u>3-24-75</u>		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>steel</u> Height: Above or Below _____ Threaded _____ Welded _____ Surface <u>18</u> in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. <u>16</u> in. to <u>153</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>7</u>		
			10. Screen: Manufacturer's name _____ <u>Doerrs</u> Type <u>steel</u> Dia. _____ Slot/gauge <u>3/16</u> Length <u>60</u> Set between <u>93</u> ft. and <u>153</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>3/4 3/8</u>		
			11. Static water level: _____ mo./day/yr. <u>163</u> ft. below land surface Date <u>1-3-75</u>		
			12. Pumping level below land surfaces: <u>27</u> ft. after <u>1</u> hrs. pumping <u>800</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>1600</u> g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>1-3-75</u>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: ft. <u>500</u> Direction <u>ne</u> Type <u>septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>W.L.R.</u> Model number <u>4-120M</u> HP <u>60</u> Volts _____ Length of drop pipe <u>60</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosencrantz-Bemis</u> <u>134</u> Business name License No. Address <u>Great Bend, Kans. 67530</u> Signed <u>S. Kilgore</u> Date <u>6-19-79</u> Authorized representative			

T 27 S R 18 E W 21 C NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5