

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: Kiowa	Fraction: S1/4 S1/4 NW1/4	Section number: 3	Township number: T 27 S	Range number: R 19 W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Vernon Davis R.R. or street: Kinsley Kansas City, state, zip code: Kinsley Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 5 1/8" Completion date: 7-12-11-78 Well depth: 69 ft.	
		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material PI Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Height 1.5 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 200	
5. Type and color of material			From	To	10. Screen: Manufacturer's name: SunFlower Plastics Type: RMP Dia. 5" Slot gauze 1/8" Length 20' Set between 40 ft. and 60 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4x3/4
Top			0	2	11. Static water level: 25 ft. below land surface Date: 12-11-78
Dark Br. Clay			2	8	12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 4 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 10 g.p.m.
Br. Clay (Sandy)			8	18	13. Water sample submitted: ___ Yes <input checked="" type="checkbox"/> No Date ___
Sand			18	23	14. Well head completion: 18 inches above grade <input type="checkbox"/> Pitless adapter
Clay			23	24	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Sand			24	27	16. Nearest source of possible contamination: L15 Stock ft. Direction: ___ Type: ___ Well disinfected upon completion? ___ Yes <input checked="" type="checkbox"/> No
Clay			27	28	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name: ___ HP: ___ Volts: ___ Length of drop pipe: ___ ft. capacity: ___ g.p.m. Type: ___ Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other
Sand			28	42	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Hayes Water Well Inc 224 Business name: 605 So. Maple Greensburg License No.: Address: Carl Hayes Date: 12-11-78 Signed: Carl Hayes Authorized representative
Clay			42	43	
Sand			43	60	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

22 19 W
 Sec 3
 S1/4 NW1/4

Forward the white, blue and pink copies to the Department of Health and Environment