

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction C/NE 1/4 1/4 1/4	Section number 12	Township number T 27 S	Range number R 19 E/W
2. Distance and direction from nearest town or city: 7 NORTH - 4 WEST OF GREENSBURG			3. Owner of well: Dewain Davis R.R. or street: Rt. 1 City, state, zip code: Mullinville, Ks.			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 29 in. Completion date _____ Well depth 155 ft. 10-20-76		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 18 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 155 ft. depth Wall Thickness, inches or Dia. _____ in. to _____ ft. depth gage No. 7		
Sandy Top ϕ Soil		0	5	10. Screen: Manufacturer's name Doerrs Type steel Dia. 16 Slot/gauge 3/16 Length 72 Set between 83 ft. and 155 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8		
Brown Clay		5	30	11. Static water level: _____ mo./day/yr. 51 ft. below land surface Date 10-7-76		
Sand Gravel		30	40	12. Pumping level below land surfaces: 13 ft. after 1 hrs. pumping 1000 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1200 g.p.m.		
Brown Clay		40	48	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 10-7-76		
Sand Brown Yellow Clay		48	53	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Sand Gravel		53	68	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Yellow Gravy Clay		68	69	16. Nearest source of possible contamination: ft. 1000 Direction NORTH Type CORRAL Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Sand Gravel		69	87	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Brown Clay Sand Gravel		87	90	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosecrantz-Bemis 134 Business name License No. Address Great Bend, Ks. Signed Freddie Hodson Date 11/10/76 Authorized representative		
Brown Clay		90	98			
Sand Gravel		98	114			
Brown Clay		114	123			
Sand Gravel		123	140			
Brown Clay		140	143			
Sand Gravel Brown Clay		143	153			
Yellow Clay (Use a second sheet if needed)		153	158			
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 27
 R 19
 E/W
 Sec 12
 C/NE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5