

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction 1/4 C 1/4 SE 1/4	Section number 27	Township number T 27 S R 19 E/W	Range number 19
2. Distance and direction from nearest town or city: 3n-4w-1n- og greelnburg, Ks. Street address of well location if in city:				3. Owner of well: Butch Pyle R.R. or street: 106 Plaza Terrace City, state, zip code: odge City, Ks. 67801		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>29</u> in. Completion date <u>4-25-77</u> Well depth <u>163</u> ft.		
		<p>7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>16</u> in. to <u>163</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>7</u></p>		10. Screen: Manufacturer's name <u>W.A. Brown</u> Type <u>steel</u> Dia. <u>16</u> Slot/gauze <u>3/16</u> Length <u>60</u> Set between <u>103</u> ft. and <u>163</u> ft. ft. and <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>3/4-3/8-1/2</u>		
				11. Static water level: <u>60</u> ft. below land surface Date <u>2-15-77</u> mo./day/yr.		
5. Type and color of material		From	To	12. Pumping level below land surfaces: <u>76</u> ft. after <u>1</u> hrs. pumping <u>800</u> g.p.m. <u>80</u> ft. after <u>2</u> hrs. pumping <u>1000</u> g.p.m. Estimated maximum yield <u>1400</u> g.p.m.		
Sandy top soil		0	8	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>2-15-77</u> mo./day/yr.		
Brown clay		8	12	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Sand and brown clay		12	18	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Brown clay		18	38	16. Nearest source of possible contamination: ft. <u>1 1/2</u> miles Direction <u>nw</u> Type <u>corral</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sand and gravel		38	109	17. Pump: Not installed Manufacturer's name <u>W.L.R.</u> Model number <u>8-TODH</u> HP <u>80</u> Volts Length of drop pipe <u>120</u> ft. capacity <u>1100</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Brown clay		109	130	(Use a second sheet if needed)		
Sand and gravel medium coarse		130	163			
Yellow brown clay		163		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosencrantz-Bemis 134</u> Business name License No. Address <u>Great Bend, Ks. 67530</u> Signed <u>Sandy K. [Signature]</u> Date <u>5-8-77</u> Authorized representative		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

27
 19
 27
 CSE
 1/4
 1/4
 1/4
 1/4