

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction 1/4 C 1/4 NE 1/4	Section number 34	Township number T 27 S R 19 E/W	Range number
2. Distance and direction from nearest town or city: 4 W- 3 3/4 N- West into field from Greensburg, Ks.				3. Owner of well: Butch Pyle R.R. or street: 106 Plaza Terrace City, state, zip code: Dodge City, Kansas 67801		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>				Sketch map:		
5. Type and color of material				From	To	<input checked="" type="checkbox"/> Bore hole dia. #2.37 Completion date _____ Well depth 166 ft. 9-13-77
						7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						<input checked="" type="checkbox"/> Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 1/2 in. to 166 ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. 7
						<input checked="" type="checkbox"/> Screen: Manufacturer's name _____ Doerrs Type steel Dia. 16" Slot xxx 3/16 Length 60 Set between 106 ft. and 166 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8
						11. Static water level: _____ mo./day/yr. 71 ft. below land surface Date 7-21-77
						12. Pumping level below land surfaces: 77 ft. after 1 hrs. pumping 600 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1400 g.p.m.
						13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 7-21-77
						14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
				16. Nearest source of possible contamination: ft. 1 mi Direction NW Type septic Well disinfected upon completion? HTH Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name W.L.B. Model number 5-12BH HP 80 Volts _____ Length of drop pipe 130 ft. capacity 1100 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed Sandy Pyle Date 9-30-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

27 19 E
 Sec 34
 1/4 C NE
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5