

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: Sedgwick		SW ¼ NE ¼ SE ¼	30	T 27S S	R 2W E/W
Distance and direction from nearest town or city street address of well if located within city? 1201 N. Oak St.					
2 WATER WELL OWNER: Donna Long RR#, St. Address, Box # : 1201 N. Oak St. City, State, ZIP Code : Goddard KS					
Board of Agriculture, Division of Water Resources Application Number:					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 80 ft. ELEVATION: ft.			
N NW NE W E SW SE S		Depth(s) Groundwater Encountered 23 ft. 2 ft. 3 ft.			
		WELL'S STATIC WATER LEVEL 23 ft. below land surface measured on mo/day/yr 4/27/05			
		Pump test data: Well water was ft. after hours pumping gpm			
		Est. Yield gpm: Well water was ft. after hours pumping gpm			
WELL WATER TO BE USED AS:		5 Public water supply 8 Air conditioning 11 Injection well			
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)					
2 Irrigation 4 Industrial 7 Domestic (lawn & garden) 10 Monitoring well					
Was a chemical/bacteriological sample submitted to Department? Yes No ☒ ; If yes, mo/day/yrs sample was submitted					
Water Well Disinfected? Yes ☒ No					
5 TYPE OF BLANK CASING USED:					
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued ☒ Clamped					
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded					
Blank casing diameter 5 in. to 80 ft., Dia in. to ft., Dia in. to ft.					
Casing height above land surface 16 in., weight 160 lbs./ft. Wall thickness or gauge No. 26					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel 3 Stainless Steel 5 Fiberglass 7 PVC 10 Asbestos-Cement					
2 Brass 4 Galvanized Steel 6 Concrete tile 8 RMP (SR) 11 Other (Specify)					
12 None used (open hole)					
SCREEN OR PERFORATION OPENINGS ARE:					
1 Continuous slot 3 Mill slot 5 Guazed wrapped 8 Saw cut 11 None (open hole)					
2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes					
10 Other (specify)					
SCREEN-PERFORATED INTERVALS: From 40 ft. to 80 ft., From ft. to ft.					
GRAVEL PACK INTERVALS: From 24 ft. to 80 ft., From ft. to ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other					
Grout Intervals: From 4 ft. to 24 ft., From ft. to ft., From ft. to ft.					
What is the nearest source of possible contamination:					
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well					
2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well					
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)					
13 Insecticide storage					
Direction from well? South How many feet? 20					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	topsoil			
2	23	clay			
23	27	Fine sand			
27	34	clay			
34	41	Fine-med sand			
41	80	blue shale			

7. CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 4/27/05 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's Licence No. 6611 This Water Well Record was completed on (mo/day/yr) 5/11/05 under the business name of Chase Drilling by (signature) R. Chase