

1	LOCATION OF WATER WELL: Sedgwick	FRACTION NE 1/4 NW 1/4 SE 1/4	SECTION NUMBER 1	TOWNSHIP NUMBER T 27 S	RANGE NUMBER R 2W E/W
---	--	---	----------------------------	----------------------------------	---------------------------------

2520 N. Cedar Crest **Wichita, Kansas**

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 	<table style="width: 100%;"> <tr> <td style="width: 50%;"> 4 DEPTH OF COMPLETED WELL: 80 ft. </td> <td style="width: 50%;"> ELEVATION: _____ ft. </td> </tr> <tr> <td colspan="2"> Depth of groundwater Encountered: _____ ft. </td> </tr> <tr> <td colspan="2"> WELL'S STATIC WATER LEVEL 25 FT. BELOW LAND SURFACE MEASURED ON mo/day/yr: 11/2/11 </td> </tr> <tr> <td> Pump test data: </td> <td> Well water was _____ ft. after _____ hours of pumping @ _____ gpm </td> </tr> <tr> <td> Est. Yield: _____ gpm </td> <td> Well water was _____ ft. after _____ hours of pumping @ _____ gpm </td> </tr> <tr> <td colspan="2"> Bore Hole Diameter 12 in. to 116 ft. and _____ in. to _____ ft. </td> </tr> <tr> <td colspan="2"> WELL WATER TO BE USED AS: </td> </tr> <tr> <td> 1. Domestic </td> <td> 3. Feedlot </td> </tr> <tr> <td> 2. Irrigation </td> <td> 4. Industrial </td> </tr> <tr> <td> 5. Public water supply </td> <td> 6. Oil field water supply </td> </tr> <tr> <td> 7. Lawn and garden only </td> <td> 8. Air conditioning </td> </tr> <tr> <td> 9. Dewatering </td> <td> 10. Monitoring well </td> </tr> <tr> <td> 11. Injection well </td> <td> 12. Other (Specify below) </td> </tr> </table>	4 DEPTH OF COMPLETED WELL: 80 ft.	ELEVATION: _____ ft.	Depth of groundwater Encountered: _____ ft.		WELL'S STATIC WATER LEVEL 25 FT. BELOW LAND SURFACE MEASURED ON mo/day/yr: 11/2/11		Pump test data:	Well water was _____ ft. after _____ hours of pumping @ _____ gpm	Est. Yield: _____ gpm	Well water was _____ ft. after _____ hours of pumping @ _____ gpm	Bore Hole Diameter 12 in. to 116 ft. and _____ in. to _____ ft.		WELL WATER TO BE USED AS:		1. Domestic	3. Feedlot	2. Irrigation	4. Industrial	5. Public water supply	6. Oil field water supply	7. Lawn and garden only	8. Air conditioning	9. Dewatering	10. Monitoring well	11. Injection well	12. Other (Specify below)
4 DEPTH OF COMPLETED WELL: 80 ft.	ELEVATION: _____ ft.																										
Depth of groundwater Encountered: _____ ft.																											
WELL'S STATIC WATER LEVEL 25 FT. BELOW LAND SURFACE MEASURED ON mo/day/yr: 11/2/11																											
Pump test data:	Well water was _____ ft. after _____ hours of pumping @ _____ gpm																										
Est. Yield: _____ gpm	Well water was _____ ft. after _____ hours of pumping @ _____ gpm																										
Bore Hole Diameter 12 in. to 116 ft. and _____ in. to _____ ft.																											
WELL WATER TO BE USED AS:																											
1. Domestic	3. Feedlot																										
2. Irrigation	4. Industrial																										
5. Public water supply	6. Oil field water supply																										
7. Lawn and garden only	8. Air conditioning																										
9. Dewatering	10. Monitoring well																										
11. Injection well	12. Other (Specify below)																										

5		TYPE OF CASING USED:				CASING JOINTS:		Glued		Threaded	
1. Steel		3. RPM (SR)		5. Wrought Iron		7. Fiberglass		9. Other (Specify below)		Welded	
2. PVC		4. ABS		6. Asbestos-Cement		8. Concrete tile		SDR-26		Clamped	
Blank casing diameter		5 in.		to 60 ft.,		Dia. in.		to ft.,		Dia. in.	
Casing height above land surface:		12 in.,		Weight:		2.35 lbs. / ft.		Wall thickness or gauge No.		.214	
TYPE OF SCREEN OR PERFORATION MATERIAL:											
1. Steel		3. Stainless Steel		5. Fiberglass		7. PVC		9. ABS		11. Other (specify)	
2. Brass		4. Galvanized		6. Concrete Tile		8. RMP (SR)		10. Asbestos-Cement		12. None used (open hole)	
SCREEN OR PERFORATION OPENINGS ARE:											
1. Continuous slot		3. Mill slot		5. Gauzed wrapped		7. Torch cut		9. Drilled holes		11. None (open hole)	
2. Louvered shutter		4. Key punched		6. Wire wrapped		8. Saw cut		10. Other (specify)			
SCREEN - PERFORATION INTERVAL		From		60 ft.		to 80 ft.,		From		ft.	
		From		ft.		to ft.,		From		ft.	
GRAVEL PACK INTERVALS:		From		24 ft.		to 80 ft.,		From		ft.	
		From		ft.		to ft.,		From		ft.	

6	GROUT MATERIALS:										
	1. Neat cement		2. Cement Grout		3. Bentonite		Other bentonite hole plug				
	Grout Intervals:	From 4 ft.	to 24 ft.	From	ft.	to	ft.	From	ft.	to	ft.
	What is the nearest source of possible contamination:										
	1. Septic tank	4. Lateral lines	7. Pit privy	10. Livestock pens	13. Insecticide storage	15. Oil well/Gas well					
	2. Sewer lines	5. Cess Pool	8. Sewage lagoon	11. Fuel storage	14. Abandon water well	16. Other (specify below)					
	3. Watertight sewer line	6. Seepage pit	9. Feed yard	12. Fertilizer storage							
	Direction from well? East				How many feet? 50 ft. plus						

[illegible]

Todd S. Harp