


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>FORD</b>	Fraction <b>SW 1/4 NW 1/4 NE 1/4</b>	Section number <b>24</b>	Township number <b>T 27 S R 21 W E/W</b>	Range number
2. Distance and direction from nearest town or city:		<b>2 1/2 W - 6 S</b>		3. Owner of well: <b>Wes Hefner</b>		
Street address of well location if in city:		<b>1/2 E - 1/8 S Windthorst</b>		R.R. or street: <b>RFD</b> City, state, zip code: <b>FORD, KS.</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>8</b> in. Completion date: Well depth <b>3-18-82</b> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
<b>top soil</b>		<b>0</b>		<b>10</b>		9. Casing: Material <b>PVC</b> Height: <b>above</b> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <b>2.9</b> lbs./ft. Dia. <b>5</b> in. to <b>106</b> ft. depth Wall Thickness: inches or Dia. <b>5</b> in. to <b>106</b> ft. depth gage No. <b>SOR21</b>
<b>clay</b>		<b>10</b>		<b>50</b>		10. Screen: Manufacturer's name <b>Peenless</b> Type <b>PVC</b> Dia. <b>5</b> Slot/gauze <b>20</b> Length <b>20</b> Set between <b>86</b> ft. and <b>106</b> ft. ft. and <b>106</b> ft. Gravel pack? <b>Yes</b> Size range of material <b>1/4"</b>
<b>sandy clay</b>		<b>50</b>		<b>80</b>		11. Static water level: <b>56</b> ft. below land surface Date <b>3-18-82</b> mo./day/yr.
<b>sand + gravel</b>		<b>80</b>		<b>106</b>		12. Pumping level below land surfaces: <b>56</b> ft. after <b>3</b> hrs. pumping <b>16</b> g.p.m. ft. after <b>16</b> hrs. pumping <b>16</b> g.p.m. Estimated maximum yield <b>16</b> g.p.m.
<b>shale</b>		<b>107</b>				13. Water sample submitted: <b>Yes</b> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <b>12</b> inches above grade
						15. Well grouted? <b>Yes</b> With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.
						16. Nearest source of possible contamination: <b>NONE</b> ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <b>Not installed</b> Manufacturer's name <b>Goulds</b> Model number <b>10ET</b> HP <b>3/4</b> Volts <b>230</b> Length of drop pipe <b>84</b> ft. capacity <b>16</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		<b>Whitewater Pitless unit used</b>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>BRAU DRILLING CO 217</b> Business name <b>BUCKLIN KS</b> License No. Address <b>Pleasant</b> <b>548</b> Signed <b>Pleasant</b> Authorized representative		