


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Ford	County Ford	Fraction SE_{1/4} SE_{1/4} SE_{1/4}	Section number 8	Township number T 27 S R 22 E 10
2. Distance and direction from nearest town or city: 1N, 1/2E, 3N of Ford, Kansas Street address of well location if in city:			3. Owner of well: Steve Riegel R.R. or street: R. R. City, state, zip code: Ford, Kansas 67842	
4. Locate with "X" in section below: Sketch map: <div style="text-align: center;"></div> 330' N and 1175' W of SE corner of SE_{1/4}, Sec. 8, T27S, R22W, Ford County, Kansas.			6. Bore hole dia. .28 in. Completion date 10-15-77 Well depth 200 ft.	
5. Type and color of material			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>	
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 108 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219	
			10. Screen: Manufacturer's name Cook/Doerr Type Louver/Wirewrap Dia. 16" Slot/gauze 1/16 Length 92 Set between 108 ft. and 200 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 2.5mm	
			11. Static water level: 34 ft. below land surface Date 5-13-77	
			12. Pumping level below land surfaces: 170 ft. after 1/2 hrs. pumping 604 g.p.m. 176 ft. after 1 hrs. pumping 664 g.p.m. Estimated maximum yield 550 g.p.m.	
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
			14. Well head completion: Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
(Use a second sheet if needed)			15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.	
			16. Nearest source of possible contamination: Unknown ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
			17. Pump: Not installed Manufacturer's name Layne & Bowler Model number 10 KEH HP 60 Volts 460 Length of drop pipe 190 ft. capacity 550 g.p.m. Type: Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other <input type="checkbox"/>	
			18. Elevation:	
19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. #102 Layne-Western Company, Inc. Business name Address Garden City, Ks. 67846 Signed [Signature] Date 13 Oct 77 Authorized representative	