


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 27	Township number T 27 S	Range number R 22 W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div> 			Sketch map: Duane Riegel (Steve Riegel) Ft. Dodge Road Dodge City, Kansas			
5. Type and color of material			From	To	6. Bore hole dia. 9 1/8 in. Completion date 10/20/75 Well depth 131 ft.	
Top soil			0	5	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Gypsum			5	20	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Fine sand			20	30	9. Casing: Material RMP Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <input type="checkbox"/> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 131 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>	
Gypsum & sandy clay			30	57	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5" Slot/gauze fine Length 70' Set between 61 ft. and 131 ft. Gravel pack? yes Size range of material 3 1/16"	
Dakota sand			57	130	11. Static water level: 43 ft. below land surface Date 10/15/75 mo./day/yr.	
Blue clay			130	140	12. Pumping level below land surface: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____	
					14. Well head completion: ____ Pitless adapter ____ Inches above grade	
					15. Well grouted? yes With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.	
					16. Nearest source of possible contamination: none ft. ____ Direction ____ Type ____ Well disinfected upon completion? ____ Yes ____ No	
					17. Pump: ____ Not installed Manufacturer's name Aermotor Model number SD19-100 HP 1 Volts 220 Length of drop pipe 105 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation: Topography: ____ Hill ____ Slope <input checked="" type="checkbox"/> Upland ____ Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name Wheeler Kansas License No. 67864 Address 10-22-75 Signed [Signature] Date 10-22-75 Authorized representative		