

23842

[illegible]

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

• P.O. Box A

• GARDEN CITY, KANSAS 67846

John Schmidt
Ford County
9-7-07

Location: SW $\frac{1}{4}$ 4-27-22 - Spearville Road North of Ford - Corner By
Feedyard - 4 miles north, $\frac{1}{2}$ mile east,
1,044 ft. north & 30 ft. west to well.
- Offset - 8 ft. west & 154 ft. north

Static Water Level - 104 ft.

Test #2

0' to 3' - Top soil
3' to 26' - Brown clay
26' to 29' - Fine to medium sand & gravel
29' to 34' - Brown clay-yellow rock strips - hard pull down 200
34' to 38' - Brown clay
38' to 46' - Brown clay-yellow rock strips - hard pull down 275
46' to 48' - Yellow clay
48' to 53' - Shale - hard pull down 200
53' to 138' - Shale - Dakota sand stone strips - hard pull down 200
138' to 156' - Shale - 20% Dakota sand stone - hard pull down 200
156' to 213' - Shale - Dakota sand stone streak - pull down 200
213' to 218' - Dakota sand stone - pull down 200
218' to 234' - Dakota sand stone - pull down 225
234' to 240' - Yellow clay
240' to 254' - Yellow gray red clay
254' to 276' - Shale - hard pull down 200
276' to 318' - Gray shale - hard pull down 200
318' to 383' - Shale - 90% Dakota sand stone - loose
383' to 400' - Gray shale
400' to 410' - Red bed