WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction Center of		Section number		Township number	Range number	
1. Location of well:	Ford	1/4 1/4 NW	1/4	11		T 27 S	R 23 E	$\mathbf{\hat{Q}}$
12 miles Southeast of Dodge City Street address of well location if in city: R.R. or s						Paul Kisslinger Route 1 Larned, KS 67550		
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. <u>24</u> in. Well depth <u>66</u> ft.	Completion date <u>9-6-</u> (Pump Set 5-25	7 7 -78)
□						7Cable toolRotaryDrivenDugHollow rodJettedBored X_Reverse rotary 8. Use:DomesticPublic supplyIndustry XIrrigationAir conditioningStock		
S 1 Mile						Lawn Oil field water Other 9. Casing: Material steel Height Abov or below Threaded Welded X Surface 12 in. RMP PVC Weight 30 . 3 lbs./ft. Dia . 16 in. to 48 ft. depth Wall Thickness: inches or		
Top soil				0	2	Double-slot	Dia. 16"	_
Brown & white clay & limestone streaks				2	39	Set between D 48ft. andft.		
Sand & gravel				39	42	Gravel pack (*Yes_ Size ran	nge of material 3/8-20	Ö
Sand & gravel with thin limestone streaks				42	66	11. Static water level:36ft. below land sur		т. -
						12. Pumping level below land	surfaces: N/C rs. pumping g.p.r	
						Estimated maximum yield		n.
						***	Date	-
							12 Inches above grade	┦.
						15. Well grouted? $\underline{\underline{Yes}}$ With: $\underline{\underline{X}}$ Neat cement $\underline{\underline{\hspace{0.5cm}}}$ Depth: From $\underline{\underline{\hspace{0.5cm}}}$ ft. to	Bentonite Concret	
						16. Nearest source of possible	contamination: Field	6
Property and the second						Well disinfected upon comple		40
						17. Pump: Manufacturer's name <u>Berk</u> Model number <u>6S2AL-6</u>	Not installed eley Pump Co. _ HP _15 Volts 46	\mathcal{G}^{*}
						Length of drop pipe 52	ft. capacity 200g.p.m	
						Type: X Submersible	Turbine	
(Use a second sheet if needed)						Jet Centrifugal	Reciprocating	│ ऽं/ू
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report		
Topography: Hill Slope Upland						is true to the best of my know Clarke Well & E Business name Address Great Bend, Signed		7 2 -
Valley						Authorized repr		7 2 -