WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction NE		Section	number	Township number	Range number		
1. Location of well:	Ford	SE 1/4 SW 1/4 NAX	1/4	11		_T 27 _s	_R 23		
2. Distance and direction from nearest town or city: 12 miles SE of Dodge City 3. Owner o									
Street address of well location if in city:					Tamed VC 67550				
City, state, z 4. Locate with "X" in section below: Sketch map:					code; -	6 Bore hole dia 24	Completion date		
4. Locate with "A" in section below: Sketch map:						6. Bore hole dia $5\frac{24}{52}$ in.	8-30	77	
T :						7 Cable tool Rotary Driven Dug			
NW NE E						Hollow rod Jetted Bored X_Reverse rotary			
						8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock			
						Lawn Oil field water Other 9. Casing: Material Stee Height Above or below			
						Threaded Welded _X Surface in.			
S						RMP			
1→ 1 Mile → 1				From	То	Dia. 16 n. to 52 ft. dep	th!Wall Thickness: inc th!gage No. / ga.	hes or	
5. Type and color of material				rion	"	10. Screen: Manufacturer's name Cook			
top soil				0	4	Type Double-slot Dia. 16"			
sandy clay, limestone, white clay				4	30	Slof gauze 1/8	_ Length		
				30	32	Ser between			
sand, gravel loose limestone				-50	32	Gravel pack? <u>yes</u> Size ra	nge of material 3/0	200	
hard cemented gravel				32	40	11. Static water level: 27 ft. below land surface Date 8-30-77			
good sand gravel				40	47	12. Pumping level below land surfaces: NC			
blue shale; brown clay				47	52	ft. after h		g.p.m.	
Management of the Control of the Con				1		Estimated maximum yield —		g.p.m.	
					3	13. Water sample submitted: YesX No	mo./ Date	/day/yr.	
The contract of the contract o				1 1 2		14. Well head completion:	12		
The second secon						Pitless adapter 15. Well grouted?	LZ Inches above g	grade	
The second secon						With: X Neat cement Bentonite Concrete			
				1	¥	Depth: From <u>0</u> ft. to <u>10</u> ft.			
						16. Nearest source of possible contamination: ft Direction Type			
			4.2	ໃນເຕເລີ		Well disinfected upon comple	Х	No	
						17. Pump: Manufacturer's name Pee	rless Pump		
						Model number 10LB-6	HP30400	, 460 N	
						Length of drop pipe	ff. capacity	·g.p.m·	
						Submersible	X Turbine	1 1	
(Use a second sheet if needed)						Jet Centrifugal	Reciprod	cating	
18. Elevation: 19. Remarks:					•	20. Water well contractor's			
					This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
Topography:						Clarke Well & Equip., Inc. 185			
Hill						Business name Great B	end KS 67	<u>~986.</u> ≥	
Upland						Signed OW/	lak 11	<u>/1/7</u> 7_ 8	
Valley						Authorized rep	resentative		