

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BDC

1. Location of well:	County Ford	Fraction SW 1/4 SE 1/4 NW 1/4	Section number 19	Township number T 27 S	Range number R 23 E
2. Distance and direction from nearest town or city: 1.7 SE-2 S-1/4 E of Ft. Dodge, Ks Street address of well location if in city:			3. Owner of well: Eugene Jones R.R. or street: Dodge City, Kansas City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:			6. Bore hole dia. 28 in. Completion date _____ Well depth 160 ft. 1-14-77 7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary _____ 8. Use: Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____ 9. Casing: Material Metal Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. _____ RMP _____ PVC _____ Weight 31.66 lbs./ft. _____ Dia. 16 in. to 160 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 188		
5. Type and color of material			From	To	10. Screen: Manufacturer's name _____ W.A. Brown Type 10% Free-flow Dia. 16 Slot/gauze 1/8 Length 160 ft. _____ Set between _____ ft. and _____ ft. _____ Gravel pack? yes Size range of material 1/2 down
Surface			0	3	11. Static water level: _____ mo./day/yr. 20 ft. below land surface Date 1-14-77
Fine to 1/2 med. sand and gravel			3	21	12. Pumping level below land surfaces: 25 ft. after 2 hrs. pumping 850 g.p.m. 290 ft. after 1 hrs. pumping 2000 g.p.m. Estimated maximum yield 2500 g.p.m.
Brown coleche clay			21	40	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
Fine sand with 10% clay mixed			40	71	14. Well head completion: _____ Pitless adapter <input checked="" type="checkbox"/> Inches above grade _____
Sandy brown clay			71	76	15. Well grouted? yes With: Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete _____ Depth: From 0 ft. to 10 ft.
Fine sand with some clay layers mixed			76	97	16. Nearest source of possible contamination: _____ ft. _____ Direction NE Type NA Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No _____
Fine to 1/2 med. sand and gravel			97	105	17. Pump: _____ Not installed Manufacturer's name Goulds Model number 12J10 HP 80 Volts _____ Length of drop pipe 160 ft. capacity 850 g.p.m. Type: _____ <input checked="" type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet _____ Reciprocating <input checked="" type="checkbox"/> Centrifugal _____ Other _____
Brown clay			105	108	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. Address Dodge City, Kansas Signed Carl G. Little Date 1-18-77 Authorized representative
Good sand and gravel			108	157	
Yellow clay			157	159	
Blue shale			159	165	
Brock 157'					
20'					
137' cut / thick					
in Og					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: ____ Hill ____ Slope <input checked="" type="checkbox"/> Upland ____ Valley	Topo 2455 157 2290				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5