


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 24	Township number T 27 S R 23	Range number E/W
2. Distance and direction from nearest town or city: 3 1/2 mi. Northwest of Ford, Kansas Street address of well location if in city:				3. Owner of well: Elmer O. Riegel R.R. or street: 1201 5th St. City, state, zip code: Dodge City, Kansas 67801		
4. Locate with "X" in section below:		Sketch map:		6. Hole dia. 26 in. Completion date 3/29/76 Well depth 253 ft.		
		NE corner		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
sand, clay				0	20	9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <input type="checkbox"/> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.86 lbs./ft. Dia. 16 in. to 253 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
gyp				20	40	10. Screen: Manufacturer's name Lakewood Type Millalet Dia. 16 in. Slot gauge 1/8 x 2 Length 170 ft. Set between 83 ft. and 253 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material # 1-1
shale				40	60	11. Static water level: <input type="checkbox"/> mo./day/yr. 38 ft. below land surface Date 2/25/76
sandstone, clay				60	100	12. Pumping level below land surfaces: 247 ft. after 6 hrs. pumping 800 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 800 g.p.m.
clay & sandstone				100	200	13. Water sample submitted: See Remarks /day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date
sandstone to sandy clay clay hard 250				200	253	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: NA ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type None in field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply Inc Business name License No. 136 Address 402 N 3rd Garden city, Ks. Signed David H. Harkness Date 4-27-76 Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Water sample will be sent as soon as Mr. Riegel starts his well. It will be approximately 2 weeks weeks				