

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County FORD	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 3	Township number 29	Range number 24	EW 0
2. Distance and direction from nearest town or city:		Street address of well location if in city:		3. Owner of well:			
		WILKRODS GARDENS		HERMAN BARRETT			
				R.R. or street: RT 3			
				City, state, zip code: Dodge City KS 67801			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date Well depth 140 ft. 11-9-79			
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 92 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 4 in. to 140 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250			
5. Type and color of material		From	To	10. Screen: Manufacturer's name PEERLESS PVC			
TOP SOIL		0	3	Type PVC Dia. 4"			
CLAY & SAND		3	15	Slot/gauze 1/16" Length 20'			
GRAVEL		15	25	Set between 120 ft. and 140 ft.			
CLAY		25	35	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"			
SAND		35	60	11. Static water level: 25 ft. below land surface Date 11-9-79			
GRAVEL		60	140	12. Pumping level below land surfaces: 25 ft. after 1 hrs. pumping 20 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 25 g.p.m.			
				13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/>			
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12" Inches above grade			
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
				16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type UNKNOWN Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Goulds Model number 10ET HP 3/4 Volts 230 Length of drop pipe 126 ft. capacity 25 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BRAD DRILL CO 217 Business name BUCKLIN KS License No. <input type="checkbox"/> Address PIEBRAW Date 11-11-79 Signed PIEBRAW Authorized representative			
19. Remarks:							
OWNER AGREED TO INSTALL 4' X 4' X 4" Reinforced concrete PAD AROUND CASING							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5