


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 4	Township number T 27 S R 24 E	Range number 24
2. Distance and direction from nearest town or city: 1 Mile East of Dodge City			3. Owner of well: MBPXL Corporation R.R. or street: P. O. Box 1080 City, state, zip code: Dodge City, Kansas 67801			
4. Locate with "X" in section below: 			Sketch map: Dakota One			6. Bore hole dia: 7-7/8" Completion date: 3/6/80 Well depth: 324 1/2 ft.
5. Type and color of material			From			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Soil			0			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other
Fine sand			3			9. Casing: Material <input type="checkbox"/> Threaded <input checked="" type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 2 in. to 10 ft. depth Wall Thickness: inches or Dia. 2 in. 236 ft. depth 218 PVC
Med. to coarse sand & gravel w/boulders			8			10. Screen: Manufacturer's name GATOR Type Slotted PVC Dia. 2" Slot/gauze 1/16 Length 80' Set between 244.5 ft. and 324.5 ft. Gravel pack? Yes Size range of material 1/8x3/8
Tan clay			21			11. Static water level: 84 ft. below land surface Date 9/20/80
Tan clay with fine sand streaks			35			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield None g.p.m.
Med. to coarse sand w/some clay			65			13. Water sample submitted: ____ mo./day/yr. ____ Yes <input checked="" type="checkbox"/> No Date ____
Med. to coarse sand & gravel w/rock			84			14. Well head completion: 18 Inches above grade
Black shale			150			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 190'-200'
Gray shale			201			16. Nearest source of possible contamination: Waste ft. 300 Direction South Type Treatment
Gray shale w/sandstone streaks			232			Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No
Black shale w/sandstone streaks			280			17. Pump: <input checked="" type="checkbox"/> Not installed
Tan sandstone			295			Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: Monitor or Observation Well See Attached Map				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name Wichita License No. Kansas Address 1011 E. 10th Signed [Signature] Date 3/6/80 Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5