

1 LOCATION OF WATER WELL		Fraction SW $\frac{1}{4}$ lot 5	Section Number 12	Township Number T 27 S	Range Number R 24 E/W		
County: Ford		$\frac{1}{4}$	$\frac{1}{4}$	$\frac{1}{4}$			
Distance and direction from nearest town or city? 5 mi SE Dodge City on Wilroams RD.			Street address of well if located within city?				
2 WATER WELL OWNER: Harry Riley			Board of Agriculture, Division of Water Resources				
RR#, St. Address, Box #: 2213 Crescent Dr.			Application Number: 29500				
City, State, ZIP Code: Dodge City, Ks 67801							
3 DEPTH OF COMPLETED WELL: 144 ft. Bore Hole Diameter: 28 in. to 144 ft. and in. to ft.							
Well Water to be used as:							
1 Domestic		3 Feedlot		5 Public water supply			
2 Irrigation		4 Industrial		6 Oil field water supply			
		7 Lawn and garden only		8 Air conditioning			
				9 Dewatering			
				10 Observation well			
				11 Injection well			
				12 Other (Specify below)			
Well's static water level 9 ft. below land surface measured on 2-22-80 month day year							
Pump Test Data: Well water was 100 ft. after 3 hours pumping 1800 gpm							
Est. Yield 2200 gpm: Well water was ft. after hours pumping gpm							
4 TYPE OF BLANK CASING USED:							
1 Steel		3 RMP (SR)		5 Wrought iron			
2 PVC		4 ABS		6 Asbestos-Cement			
				7 Fiberglass			
				8 Concrete tile			
				9 Other (specify below)			
				Casing Joints: Glued Clamped			
				Welded X			
				Threaded			
Blank casing dia 16 in. to 64 in. to ft. Dia in. to ft.							
Casing height above land surface 14 in. weight 31.66 lbs./ft. Wall thickness or gauge No 188							
TYPE OF SCREEN OR PERFORATION MATERIAL:							
1 Steel		3 Stainless steel		5 Fiberglass			
2 Brass		4 Galvanized steel		6 Concrete tile			
				7 PVC			
				8 RMP (SR)			
				9 ABS			
				10 Asbestos-cement			
				11 Other (specify)			
				12 None used (open hole)			
Screen or Perforation Openings Are:							
1 Continuous slot		3 Mill slot		5 Gauzed wrapped			
2 Louvered shutter		4 Key punched		6 Wire wrapped			
				7 Torch cut			
				8 Saw cut			
				9 Drilled holes			
				10 Other (specify)			
				11 None (open hole)			
Screen-Perforation Dia 16 in. to 144 ft. Dia in. to ft.							
Screen-Perforated Intervals: From 64 ft. to 144 ft. From ft. to ft. From ft. to ft. From ft. to ft.							
Gravel Pack Intervals: From 10 ft. to 144 ft. From ft. to ft. From ft. to ft.							
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other							
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.							
What is the nearest source of possible contamination:							
1 Septic tank		4 Cess pool		7 Sewage lagoon			
2 Sewer lines		5 Seepage pit		8 Feed yard			
3 Lateral lines		6 Pit privy		9 Livestock pens			
				10 Fuel storage			
				11 Fertilizer storage			
				12 Insecticide storage			
				13 Watertight sewer lines			
				14 Abandoned water well			
				15 Oil well/Gas well			
				16 Other (specify below)			
Direction from well NW How many feet 600 ? Water Well Disinfected? Yes No X							
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample was submitted month day year: Pump Installed? Yes No X							
If Yes: Pump Manufacturer's name Model No. HP Volts							
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.							
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other							
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 2 month 20 day 80 year							
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 190							
This Water Well Record was completed on 4-14-80 month day year under the business name of Ace Hi International by (signature)							
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		0	3	Surface			
		3	9	Clay			
		9	25	Coarse sand and gravel			
		25	45	Yellow clay			
		45	75	Yellow clay with 20 to 30 % sand mixed			
		75	95	Fine sand with some clay			
		95	140	Good coarse sand and gravel			
		140	145	Yellow clay			
		145	150	Blue shale			
ELEVATION:							
Depth(s) Groundwater Encountered 1. 9 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)							
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.							

OFFICE USE ONLY

T

27

R

24

27

SEC.

12

1/4

1/4

SW 1/4