


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ford	Fraction SE 1/4 NE 1/4 NW 1/4	Section number 13	Township number T 27 S	Range number R 24 E/W
2. Distance and direction from nearest town or city: 2 mi east & 1/2 south of Ft. Dodge Street address of well location if in city:			3. Owner of well: Catherine Riley (Dorthy M. Lewis-consrser.) R.R. or street: % Harry E Riley City, state, zip code: Dodge City, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 20 in. Completion date 6-16-77 Well depth 140 ft.
Surface			0	3	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Silt			3	6	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Coarse sand and gravel			6	24	9. Casing: Material Metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 20 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft. Dia. 16 in. to 140 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188
Fine sand			24	45	10. Screen: Manufacturer's name W.A. Brown Type 17% Free-flow Dia. 16 Slot/gauze 1/8 Length 100 Set between 40 ft. and 140 ft. ft. and ft.
Fine sand with 20% clay			45	69	Gravel pack? yes Size range of material 3/8 down
Fine sand			69	82	11. Static water level: mo./day/yr. 3 ft. below land surface Date 6-11-77
Sandy clay			82	88	12. Pumping level below land surfaces: 50 ft. after 2m hrs. pumping 2000 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 3000 g.p.m.
Good fine to med. sand and gravel			88	113	13. Water sample submitted: mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date
Sandstone and clay			113	117	14. Well head completion: Pitless adapter <input checked="" type="checkbox"/> Inches above grade
Good med. bottom gravel			117	137	15. Well grouted? yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
Yellow clay			137	142	16. Nearest source of possible contamination: ft. 1500 Direction north Type river Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Blue shale			142	150	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 14JMH6 HP 100 Volts 2000 Length of drop pipe 100 ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. Address Dodge City, Kansas Signed Carl E. Gittel Date 7-15-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5