USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	FORD	RICHLAND	SW¼NE¼SE¼	3	T27S	R25W

Distance and direction from nearest town or city: WITHIN Dodge City

Street address of well location if in city: Missouri + Oklahoma Streets

3 Owner of well: RON MELLORD

Address: Dodge City, Kansas

Locate with "X" in section below:



Sketch map:

4 Well depth: 150 ft. Date of completion 12/5/75
Well diameter 8 in. 5/12/75

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐ GARDEN

7 Casing: Material PVC Height: (above)/below
Threaded ☐ Welded ☐ Surface 24 in.
Diam. Blue Weight 125 lbs/ft. SDR 21
5 in. to 150 ft. depth Drive shoe? ☐ Yes ☒ No
___ in. to ___ ft. depth

2 Type and color of material	From	To
● - SOIL	0	2
CLAY + SAND	2	16
GRAVEL	16	26
CLAY	26	56
FINE SAND + clay	56	62
CLAY + ROCK	62	130
GRAVEL	130	150
Put Cement between upper		
+ LOWER GRAVELS		
(use a second sheet if needed)		

8 Screen:
Manufacturer Jess + Lowell
Type PVC Dia. 5
Slot/gauze #6 Length 30
Set between 120 ft. and 150 ft.
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material #6

9 Static water level:
30 ft. below land surface Date 12/5/75

10 Pumping level below land surfaces: N/A
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date ___

12 Well head completion:
☒ Pitless adapter 24 Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ Neat cement ☐ Bentonite ☐ ___
Depth: From 3 ft. to 13 ft.

14 Nearest source of possible contamination:
ft. 200 Direction South Type SEPTIC
Well disinfected upon completion? ☒ Yes ☐ No

15 Pump: ☐ Not installed
Manufacturer's name REDA
Model number 100 HP 1 Volts 220
Length of drop pipe 42 ft. capacity 1000 ~~gpm~~ per hour
Type:
☒ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Centrifugal ☐ Other

16 Remarks: elevation

Topography:
☐ Hill NEVER
☐ Slope
☐ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
CRAGG WELL DRILLING 111
Business name License No.
Address RT 1
Signed [signature] Date 12/5/75
Authorized representative 5/12/75

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5