


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County FORD	Township name Richland	Fraction Center S.E.	Section number 5	Town number 276	Range number 25
Distance and direction from nearest town or city: Dodge City 2 W. 3/4 N. Street address of well location if in city:				3 Owner of well: Harold Zimmer Address: Lakewood, Colo 80215		
Locate with "X" in section below: 				Sketch map:		
2				4 Well depth: 160 ft. Date of completion _____ Well diameter 28 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
surface				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
clay				7 Casing: Material ST Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface _____ in. Diam. _____ Weight _____ lbs./ft. _____ 16 in. to 80 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No _____ in. to _____ ft. depth		
dry sand				8 Screen: Manufacturer W.A. Brown Type Open End Dia. _____ Slot/gauze 1/8 Length _____ Set between 80 ft. and 160 ft. _____ Fittings: _____ Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2 down		
sand & gravel coarse				9 Static water level: 53 ft. below land surface Date _____		
shale				10 Pumping level below land surfaces: 63 ft. after 7 hrs. pumping 1330 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1330 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name HYDRO Model number _____ HP _____ Volts _____ Length of drop pipe 140 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)						
16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Johnson Drilling 183 Business name _____ License No. _____ Address Box 746 Signed Jamie Alder Date 7/10/76 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						