

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford.	Fraction Center 1/4 SE 1/4	Section number 14	Township number T 27 S	Range number R 25 E/W
2. Distance and direction from nearest town or city: 23 1/2 NW Dodge City Street address of well location if in city:				3. Owner of well: Elmer Dirks R.R. or street: RR 3 City, state, zip code: Dodge City KS 67801		
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: 6. Bore hole dia. 3 3/8 in. Completion date _____ Well depth 158 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 8 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 1 1/2 in. to 1 5/8 ft. depth Wall Thickness: inches of Dia. _____ in. to _____ ft. depth gage No. 188		
5. Type and color of material				From	To	10. Screen: Manufacturer's name W.A. Brown Type Bridge Dia. 1 1/2 Slot/gauze VS Length _____ Set between 79 ft. and 159 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/16 to 1/4
Surface				0	2	11. Static water level: _____ mo./day/yr. 8 1/2 ft. below land surface Date 4/12/76
Silty Clay				2	36	12. Pumping level below land surfaces: 100 ft. after 2 hrs. pumping 1100 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1500 g.p.m.
Dry Sand				36	66	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Sand & gravel				66	74	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
Sand & gravel				74	126	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Clay & Caliche				126	132	16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
Cemented sand				132	140	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number _____ HP _____ Volts _____ Length of drop pipe 140 ft. capacity 1100 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Sand & gravel				140	156	
Clay				156	158	
Shale				158		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. J.O. Johnson Drilling 183 Business name _____ License No. _____ Address _____ Signed Janice Alden Date 6/76 Authorized representative		