


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction SW 1/4 SW 1/4 NE 1/4	Section number #25	Township number T #27	Range number S R #25 X/W	
2. Distance and direction from nearest town or city: 4 miles south and 1/2 east of Dodge City, Ks. Street address of well location if in city:			3. Owner of well: LaDonna Dirks R.R. or street: Route #3 City, state, zip code: Dodge City, Kansas 67801				
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 8 in. Completion date 8-14-75 Well depth 185 ft.			
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Top soil & clay		0	15	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Clay		15	75	9. Casing: Material RMP Height: Above 3600 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 185 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250			
Clay		75	90	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 1/8" 5" Slot/gauze 1/8" Length 21 ft. Set between 160 ft. and 180 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4"			
Clay & fine to medium sand		90	105	11. Static water level: <input type="checkbox"/> mo./day/yr. 103 ft. below land surface Date 8-14-75			
Medium sand		105	135	12. Pumping level below land surfaces: 103 ft. after 1 1/2 hrs. pumping 20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m.			
Medium to fine sand		135	150	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
Medium sand		150	165	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade			
Medium to coarse sand & clay		165	180	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 8 ft. to 18 ft.			
Clay & blue shale		180	190	16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
(Use a second sheet if needed)				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Flint & Walling Model number 7BA12 HP 3/4 Volts 230 Length of drop pipe 126 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:	19. Remarks: new building site but no buildings there when well was drilled.			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name License No. Address Box 174 Cimarron, Ks. Signed James R. Erick Date 12-20-75 Authorized representative			