

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82g-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

<b>County</b> Ford		<b>Fraction</b> NW 1/4 NW 1/4 NE 1/4		<b>Section number</b> 25		<b>Township number</b> T 27 S R 25 XEW	
<b>2. Distance and direction from nearest town or city:</b> 4 miles South & 6/10 mile east of Dodge City <b>Street address of well location if in city:</b>				<b>3. Owner of well:</b> Harold Sexton <b>R.R. or street:</b> RFD 3 <b>City, state, zip code:</b> Dodge City, KS 67871			
<b>4. Locate with "X" in section below:</b> <div style="text-align:center;"> N W      E S ← 1 Mile → E</div>				<b>Sketch map:</b> 			
<b>5. Type and color of material</b>				<b>From</b>		<b>To</b>	
Dirt and soil				0		3	
Light brown clay				3		81	
Tan, medium sand				81		185	
Blue shale				185			

(Use a second sheet if needed)

<b>18. Elevation:</b>  Topography: Hill _____ Slope _____ <input checked="" type="checkbox"/> Upland _____ Valley _____	<b>19. Remarks:</b>  Lot 1, Block 2, Wheatland Acres Sub-division Septic System also put in and approved by county
---	---

<b>6. Bore hole dia.</b> 9 in. <b>Completion date</b> 10-18-77 <b>Well depth</b> 185 ft.	
<b>7. Cable tool</b> <input checked="" type="checkbox"/> Rotary _____ Driven _____ Dug _____ _____ Hollow rod _____ Jetted _____ Bored _____ Reverse rotary _____	
<b>8. Use:</b> Domestic <input checked="" type="checkbox"/> Public supply _____ Industry _____ Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____	
<b>9. Casing: Material</b> _____ Height: Above or Below surface _____ Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 165 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0.265	
<b>10. Screen: Manufacturer's name</b> J&L sawed out Type PVC Dia. 5" Slot/gauze 1/16" Length 20' Set between 166 ft. and 185 ft. Gravel pack? yes Size range of material 1/4" down	
<b>11. Static water level:</b> mo./day/yr. 119 ft. below land surface Date 10-18-77	
<b>12. Pumping level below land surfaces:</b> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 100+ g.p.m.	
<b>13. Water sample submitted:</b> mo./day/yr. Yes XX No Date _____	
<b>14. Well head completion:</b> Pitless adapter 14 Inches above grade	
<b>15. Well grouted?</b> yes With: Neat cement Bentonite Concrete Depth: From 5 ft. to 15 ft.	
<b>16. Nearest source of possible contamination:</b> septic tank ft. 100+ Direction SE Type tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____	
<b>17. Pump:</b> Not installed Manufacturer's name Aeromotor Model number SD12-100 HP 1 Volt 230 Length of drop pipe 174 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____	
<b>20. Water well contractor's certification:</b> This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. ABC Drilling, Inc 246 Business name License No. Scott City, KS 67871 Address Sy Ross Signed Authorized representative Date 11/4/77	