


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County FORD	Fraction SE 1/4 NE 1/4 NE 1/4	Section number 25	Township number T 27 S	Range number R 25 E
2. Distance and direction from nearest town or city:		3 1/4 S - 3/4 E		3. Owner of well: WINFRED HARMON		
Street address of well location if in city:		OF DODGE CITY KS.		R.R. or street: Rt 3 City, state, zip code: Dodge City KS		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date Well depth 158 ft. 8-20-79		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
top soil		0 10		9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 92 in. RMP 5 PVC <input checked="" type="checkbox"/> Weight 150 lbs./ft. Dia. 5 in. to 150 ft. depth Wall Thickness: inches or Dia. 1258 in. to 150 ft. depth gage No. 1258		
clay		10 70		10. Screen: Manufacturer's name Perkess Type PVC Dia. 5" Slot/gauze 20' Length 20' Set between 138 ft. and 158 ft. ft. and 158 ft. Gravel pack? Yes Size range of material 1/4 to 1/2		
Sandy clay		70 90		11. Static water level: 160 ft. below land surface Date 8-20-79		
Sand & gravel		90 160		12. Pumping level below land surfaces: NOT ft. after 90' hrs. pumping NOT g.p.m. ft. after 90' hrs. pumping NOT g.p.m. Estimated maximum yield ? g.p.m.		
shale		160		13. Water sample submitted: ? mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 8-20-79		
				14. Well head completion: 12" inches above grade <input type="checkbox"/> Pitless adapter 12" inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination None ft. within 500' Direction None Type None Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ? Model number ? HP ? Volts ? Length of drop pipe ? ft. capacity ? g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BRAU Drilling 217 Business name Bucklin KS License No. 82019 Address Bucklin KS Signed RWB Date 8-20-79 Authorized representative		