

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction NE 1/4 25' East of center 1/4 1/4 1/4	Section number 29	Township number T 27	Range number S R 25	E/W E/W
2. Distance and direction from nearest town or city: 1 1/4 west - 2 1/4 south - 1/4 west of Dodge City Street address of well location if in city:				3. Owner of well: Bob Schneweis R.R. or street: RFD City, state, zip code: Dodge City, Kansas			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:				6. Bore hole dia. 28 in. Completion date 6-14-76 Well depth 250 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material Metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12.66 in. RMP 16 PVC 250 Weight 188 lbs./ft. Dia. 16 in. to 250 ft. depth Wall Thickness: inches or Dia. 16 in. to 250 ft. depth Gauge No. 188			
5. Type and color of material				From	To	10. Screens: Manufacturer's name W.A. Brown Type 17% free-flow Dia. 16 Slot/gauze 1/8 Length 120 Set between 122 ft. and 242 ft. Gravel pack? Yes Size range of material 3/8 CMA	
Surface				0	3	11. Static water level: 141 ft. below land surface Date 6-10-76	
Brown clay				3	84	12. Pumping level below land surfaces: 240 ft. after 2 hrs. pumping 550 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 550 g.p.m.	
Fine brown sand with 25 to 30% clay mixed				84	114	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
Half med. sand				114	119	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
Sandy caleche clay				119	123	15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Good med. sand and gravel				123	143	16. Nearest source of possible contamination: NA ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Med. sand and gravel with 40% brown clay				143	146	17. Pump: Not installed Manufacturer's name Goulds Model number 10JMC HP 60 Volts Length of drop pipe 240 ft. capacity 400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Sand and gravel				146	164		
Soft brown sandy clay				164	185		
Soft brown clay with 40% fine sand				185	195		
Fine sand with 20 to 50% brown clay				195	210		
Good half med. sand				210	220		
Brown clay with 35% fine sand mixed				220	226		
Half med. sand and gravel with 10% brown clay				226	239		
Brown and yellow sandy clay				239	242		
Blue shale				242	250		
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name Dodge City, Kansas License No. Address Base 6 Tith Signed Base 6 Tith Date 6-15-76 Authorized representative			