


1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number	
County: Ford		SE 1/4 SE 1/4 SE 1/4	34	T 27 S	R 25	
Distance and direction from nearest town or city? 6 miles South West of Dodge			Street address of well if located within city?			
2 WATER WELL OWNER: Dodge City Coop						
RR#, St. Address, Box #: West Trail St.			Board of Agriculture, Division of Water Resources			
City, State, ZIP Code: Dodge City, Ks 67801			Application Number:			
3 DEPTH OF COMPLETED WELL: 200 ft. Bore Hole Diameter: 8 in. to 200 ft., and in. to ft.						
Well Water to be used as:						
1 Domestic		3 Feedlot	6 Oil field water supply	9 Dewatering	11 Injection well	
2 Irrigation		4 Industrial	7 Lawn and garden only	10 Observation well	12 Other (Specify below)	
Well's static water level: 170' ft. below land surface measured on 3-12-81 month day year						
Pump Test Data: N/A						
Est. Yield: gpm: Well water was ft. after hours pumping gpm						
4 TYPE OF BLANK CASING USED:						
1 Steel		3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Casing Joints: Glued X Clamped	
PVC		4 ABS	7 Fiberglass		Welded	
Blank casing dia: 5 in. to 180 ft., Dia in. to ft., Dia in. to ft.						
Casing height above land surface: 18 in., weight 250 lbs./ft. Wall thickness or gauge No. 250						
TYPE OF SCREEN OR PERFORATION MATERIAL:						
1 Steel		3 Stainless steel	5 Fiberglass	8 RMP (SR)	10 Asbestos-cement	
2 Brass		4 Galvanized steel	6 Concrete tile	9 ABS	11 Other (specify)	
Screen or Perforation Openings Are:						
1 Continuous slot		3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)	
2 Louvered shutter		4 Key punched	6 Wire wrapped	9 Drilled holes		
			7 Torch cut	10 Other (specify)		
Screen-Perforation Dia: 5 in. to ft., Dia in. to ft., Dia in. to ft.						
Screen-Perforated Intervals: From 180 ft. to 200 ft., From ft. to ft., From ft. to ft.						
Gravel Pack Intervals: From 0 ft. to 3 ft., From ft. to ft., From ft. to ft.						
5 GROUT MATERIAL:						
1 Neat cement		2 Cement grout	3 Bentonite	4 Other		
Grouted Intervals: From 3 ft. to 15 ft., From ft. to ft., From ft. to ft.						
What is the nearest source of possible contamination:						
1 Septic tank		4 Cess pool	7 Sewage lagoon	10 Fuel storage	14 Abandoned water well	
2 Sewer lines		5 Seepage pit	8 Feed yard	11 Fertilizer storage	15 Oil well/Gas well	
3 Lateral lines		6 Pit privy	9 Livestock pens	12 Insecticide storage	16 Other (specify below)	
Direction from well: 135 ft. South How many feet? Water Well Disinfected? Yes X No						
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample was submitted month day year Pump Installed? Yes X No						
If Yes: Pump Manufacturer's name: Reda - Customers old pump Model No. unknown HP 1-1/2 Volts 220						
Depth of Pump Intake: 180' ft. Pumps Capacity rated at unknown gal./min.						
Type of pump:						
1 Submersible		2 Turbine	3 Jet	4 Centrifugal	5 Reciprocating	
6 Other						
3 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on March 12, 1981 month day year						
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 111						
This Water Well Record was completed on 3-17-81 month day year under the business name of Cragg Well Drilling by (signature) Ray Cragg						
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	LITHOLOGIC LOG
		0-3		Soil		
		3-170		Clay		
		170-183		Gravel		
		183-200		Clay		
ELEVATION:						
Depth(s) Groundwater Encountered 1. 170 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)						
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.						

OFFICE USE ONLY

T

27

R

25

SEC

34

SE 1/4 SE 1/4 SE 1/4