WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)

| | | | | | | Topeka, Kansas 66620 |
|--|---------|-----------------------------|--|----------------|---|--|
| | County | Fraction Center of SW1/4 | | Section number | | Township number Range number |
| 1. Location of well: | Ford | | | | | T 27 S R 26 EW |
| 7W on Hwy. 56, 1½N, ½E of Dodge City Street address of well location if in city: R.R. or s | | | | or street: | | Vernon Goetz 2519 Hart Street Dodge City, KS 67801 |
| 4. Locate with "X" in section below: Sketch map: | | | | | 6. Bore hole dia | |
| | | | | | 7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored <u>X</u> Reverse rotary | |
| | | | | | 8. Use: Domestic Public supply Industry | |
| XW SE I | | | | | 9. Casing: Material <u>Steel</u> Height: <u>Above or below</u> Threaded Welded Surface in. RMP PVC Weight 188 lbs./ft. | |
| 1 Mile | | | | | | Dia. 16 in. to 80 ft. depth Wall Thickness: inches or |
| 5. Type and color of material | | | | From | То | Dia in. to ft. depth gage No 100 |
| sur | Surface | | | | 2 | W. A. Brown & Johnson Johnson Dig. 16 |
| Fine, Silty Sand | | | | 2 | 26 | Slot/gauze 40% Length 20 Set between 125 ft. and 145 ft. 1/6 80 ft. and 125 ft. |
| Clay | | | | 26 | 29 | $ \frac{17\% 80}{\text{Gravel pack?} X} \text{ft. and} \frac{125}{\text{ft.}} \text{ft.} $ |
| Silty Sand | | | | 29 | 49 | 11. Static water level: mo./day/yr. 67 ft. below land surface Date 2-3-77 |
| Clay | | | | 49 | 51 | 12. Pumping level below land surfaces: |
| Clay & Caliche | | | | 51 | 57 | 145 ft. after hrs. pumping g.p.m g.p.m g.p.m. |
| Sand & Gravel | | | | 57 | 83 | Estimated maximum yieldg.p.m. 13. Water sample submitted:mo./day/yr. |
| Clay & Caliche | | | | 83 | 113 | Yes X No Date |
| Medium Sand - Some Clay Layers | | | | 113 | 121 | Pitless adapter 12 Inches above grade 15. Well grouted? |
| Medium Sand | | | | 121 | 136 | With: Neat cement X Bentonite Concrete Depth: From ft. to ft. |
| Medium Fine Sand | | | | 136 | 142 | 16. Negrest source of possible contomination: creek |
| Hard Layers & Clay | | | | 142 | 145 | Well disinfected upon completion? Yes No 17. Pump: Not installed |
| Shale | | | | 145 | | Manufacturer's name Simmons Model number S1100 HP 166 Volts |
| | | | | | | Length of drop pipe 143 ft. capacity 550g.p.m. |
| | | | | | | Type: Submersible Turbine Jet Reciprocating |
| (Use a second sheet if needed) | | | | | | Jer Kecipiocaring Centrifugal Other 6 |
| 18. Elevation: 19. Remarks: | | | | | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report |
| Topography: | | | | | | is true to the best of my knowledge and belief. Woofter Drilling, Inc. 343 |
| Hill Slope X Unland | | | | | | Business name Address HWW 56 Podge City KS |
| Upland | | | | | | Signed Authorized representative |