


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 11	Township number T 27 S R 26 E/W	Range number
2. Distance and direction from nearest town or city: 4 miles south of Howell, Ks. & 2 1/2 miles east Street address of well location if in city:				3. Owner of well: Goetz Land & Cattle, INC. R.R. or street: City, state, zip code: Dodge City, Kansas 67801		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 9 7/8 in. Completion date _____ Well depth 145 ft. 2-21-77		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top soil		0	5	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		5	50	9. Casing: Material PVC Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 145 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 265		
Sandy clay		50	90	10. Screen: Manufacturer's name Jess & Lowell Type PVC Dia. 5" Slot 1/8" Length 50' Set between 95 ft. and 145 ft. Gravel pack? Yes Size range of material #1/2 fine		
Med. to lar. sand & gravel		90	150	11. Static water level: _____ mo./day/yr. 95 ft. below land surface Date 2/17/77		
Yellow clay		150	160	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: _____ Pitless adapter 12 inches above grade		
				15. Well grouted? Yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Installed _____ Not installed Manufacturer's name Mill & Tower Model number _____ HP _____ Volts _____ Length of drop pipe 126 ft. capacity 2 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name Address Meade, Kansas 67864 License No. Signed <i>[Signature]</i> Date 2-7-77 Authorized representative		
19. Remarks:						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

27
260
1/4 1/4 1/4