


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 24	Township number T 27	Range number S 26 E/W
2. Distance and direction from nearest town or city: 4 E 3 S Dodge Street address of well location if in city:				3. Owner of well: Darrell Staggs R.R. or street: City, state, zip code: Ford, Kansas 67842		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:  Near C				6. Bore hole dia. 26 in. Completion date _____ Well depth 245 ft. 3-5-77		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: (Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 32.86 in. RMP _____ PVC _____ Weight 38.86 lbs./ft. Dia. 16 in. to 245 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .219		
				10. Screen: Manufacturer's name Lakewood Type Steel Dia. 16" Slope gauge 1/8x2" Length 111 Set between 134 ft. and 245 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/4x1/2		
				11. Static water level: _____ mo./day/yr. 130 ft. below land surface Date 1-8-77		
(Use a second sheet if needed)				12. Pumping level below land surfaces: 237 ft. after 8 hrs. pumping 600 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 600 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: 12" _____ Pitless adapter _____ Inches above grade		
				15. Well grouted? Yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: NA ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
(Use a second sheet if needed)				17. Pump: _____ Not installed Manufacturer's name Worthington Model number 6S-12L-54 HP _____ Volts _____ Length of drop pipe 230 ft. capacity 540 g.p.m. Type: _____ <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other _____		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply Inc. 136A Business name _____ License No. _____ Address 102 N 3rd Garden City, Ks Signed Barth Hahn Date 3-22-77 Authorized representative		
				18. Elevation:		
				19. Remarks:		
				Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley		

27
26
24
23
22
21
20
19
18
17
16
15
14
13
12
11
10
9
8
7
6
5
4
3
2
1
0