


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction Center 1/4 1/4 SW 1/4	Section number 28	Township number T 27 S R	Range number 26 E/W
2. Distance and direction from nearest town or city: 3E & 1N of Ensign, Kansas Street address of well location if in city:				3. Owner of well: BEL Farms R.R. or street: 508 Annette City, state, zip code: Dodge City, Kansas 67801		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 				6. Bore hole dia. 28 in. Completion date _____ Well depth 285 ft. 5-20-77		
5. Type and color of material				From	To	7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary
Surface				0	3	8. Use: _____ Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____
Silty brown clay				3	68	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia 16 in. to 0 ft. depth Wall Thickness: inches or Dia 16 in. to 140 ft. depth gauge No. 188
Fine Sand				68	153	10. Screen: Manufacturer's name _____ W. A. Brown Type Bridge Dia. 16 Slot/gauze 188 17% Length 40' Set between 140 ft. and 285 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 x 5/8
50% fine sand - 50% Brown Clay				153	165	11. Static water level: _____ mo./day/yr. 173 ft. below land surface Date 5-27-77
Fine to 1/2 fine med. sand & fine gravel				165	180	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield No test pump g.p.m.
Med to coarse sand & gravel				180	210	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No Date _____
Fine to med sand & gravel				210	230	14. Well head completion: _____ Pitless adapter 12 Inches above grade
Fine to med sand & gravel "extra good"				230	275	15. Well grouted? yes With: _____ Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.
Yellow Clay				275	278	16. Nearest source of possible contamination: ft. 3 mi Direction S to Type Farm Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No
Blue shale				278	285	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number 6-12KBH HP 125 Volts _____ Length of drop pipe 260 ft. capacity 1000 g.p.m. Type: _____ Submersible <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Woofert Drilling Inc. 343 Business name License No. _____ Address Hwy 56 Dodge City, KS Signed Michael D. Woofert Date 12/1/77 Authorized representative		
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley						