

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction N 1/2 NW 1/4	Section number 31	Township number T 27 S	Range number R 26 E
2. Distance and direction from nearest town or city: 1 3/4 S & 2 W of Sayre Street address of well location if in city:				3. Owner of well: Jimmie Reinert R.R. or street: City, state, zip code: Ensign, KS 67841		
4. Locate with "X" in section below: <div style="text-align: center;"> </div> Sketch map:				6. Bore hole dia. 26 in. Completion date _____ Well depth 300 ft. 3-23-77		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height (Above) or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 300 ft. depth Wall Thickness: inches or Dia. 16 in. to 300 ft. depth gage No. 250		
				10. Screens: Manufacturer's name Cook Type Continuous Dia. 16" Slot/gauze 125 Length 50' Set between 260 ft. and 210 ft. Gravel pack? Yes Size range of material 1/4 x 1/8		
				11. Static water level: _____ mo./day/yr. 170 ft. below land surface Date 3-26-77		
				12. Pumping level below land surfaces: 186 ft. after _____ hrs. pumping 1451 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: None observed ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name Johnston Model number 14CC HP _____ Volts _____ Length of drop pipe 265 ft. capacity _____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name _____ License No. _____ Address Box 639 Garden City, KS Signed E.L. Rathbun Date 4-7-77 Authorized representative		
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:				

DRILLERS TEST LOG

CUSTOMERS NAME Jimmie Reinert DATE 3-4-77
STREET ADDRESS _____ TEST # 2 E. LOG Yes
CITY & STATE Ensign, KS DRILLER Lee
COUNTY Ford QUARTER NW SECTION 31 TOWNSHIP 27 RANGE 26
LOCATION S side of highway in the field approx. 1100' E

[illegible]

GARDEN CITY, KS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KS
Phone 276-3278 IRRIGATION HEADQUARTERS Phone 675-4311
TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * STOCK WELLS