WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)

							Topeka, Kansas 00020	_
1. Location of well:	County	FractionCenter			Section number		Township number Range number	
200211011 01 Well:	Ford	1/4 1/4 NW		V 1/4 33		3	T 27 S R 26 E/W	/-
3E & 1N of Ensign, Ks. Street oddress of well location if in city.					ner of well: BEL Farms street: 508 Annette tote, zip code: Dodge City, Kansas 67801			
4. Locate with "X" in N	!	Sketch map:					6. Bore hole dia. 28 in. Completion date	у У
S 1 Mi	le ————————————————————————————————————				From	То	9. Casing: Material Steel Height: Above or below Threaded Welded X	1. 1.
Surface					0	3	10. Screen: Manufacturer's name W. A. Brown	-
Brown clay				3	65	Type <u>Bridge</u> Dia. <u>16</u> Slot/gauze <u>17% .188</u> Length <u>40'</u> Set between <u>160</u> ft. and <u>300</u> ft	-	
Fine Sand & 30% clay mixed				65	77	ft. and ft	r.	
K Fine Sand & 5% Clay mixed				77	131	11. Static water level: mo./day/yr		
Brown clay				131	152	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m		
Good med sand & gravel, few hard rock							ft. after hrs. pumping g.p.m Estimated maximum yield No Test Pump.p.m	.
stringers from 270' on					152	292	13. Water sample submitted: mo./day/yr	_
Yellow clay				292	294	Yes No Date 14. Well head completion:	-	
Blue shale				294	300	Pitless adapter 12_ Inches above grade 15. Well grouted? VES		
	Acres of the second						With: Neat cement _X Bentonite Concrete Depth: FromO ft. to1O ft.	<u>'</u> -
The state of the s							16. Nearest source of possible contamination: ft. 3/8-2 Direction E of Type Farm	-
A STATE OF THE STA		1					Well disinfected upon completion? Yes _X N 17. Pump: Not installed	٦,
			April 1				Manufacturer's nameWestern Land Rolls Model number 12KBH HP 125 Volts	- -
							Length of drop pipe 280 ft. capacit \ \OOO\g.p.m. Type:	
	<i>(</i> 1)						Submersible Turbine Reciprocating Other	
(Use a second sheet if needed) 18. Elevation: 19. Remarks:					1	l	20. Water well contractor's certification:	-
Topography: Hill Slope							This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Woofter Drilling Inc. 343 Business name Address Hwy 56, Dodge City, KS Signed Authorized representative	1/4 1/47