


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 1	Township number T 27 S R 27	Range number 27
2. Distance and direction from nearest town or city: 4 1/2 south of Cimarron 6 1/2 east 1/4 south Street address of well location if in city:			3. Owner of well: Louis Beery R.R. or street: 110 N Elm City, state, zip code: Cimarron, Ks. 67845		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	
					6. Bore hole dia. 26 in. Completion date 4-20-76 Well depth 180 ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 181 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>
					10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 150 ft. and 170 ft. 90-150 ft. and 170-180 ft. Gravel pack? yes Size range of material 2" Down
					11. Static water level: <input type="checkbox"/> mo./day/yr. 71 ft. below land surface Date 3-30-76
					12. Pumping level below land surfaces: 86 ft. after 3 hrs. pumping 1525 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1500 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>
					14. Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade
					15. Well yes ? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: Not installed Manufacturer's name Goulds US Pumps Model number 12MHO HP 100 Volts <input type="checkbox"/> Length of drop pipe 170 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Drilling done by Central Well and Pump Pratt, Ks.				
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name P.O. Box A Garden City, Ks. License No. 9-1-1 Address P.O. Box A Garden City, Ks. Signed [Signature] Date 4-1-76 Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MINTER-WILSON DRILLING CO.
INCORPORATED

Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

LOUIS BERRY
Gray County
1-26-76

Location: NW 1-27-27
Northeast corner

Test # 6

0	3	Top Soil
3	14	Brown Clay
14	47	Fine to Med. Sand (Loose)
47	53	Light Brown Clay
53	58	Fine to Med. Sand & Gravel
58	121	Med. Coarse Gravel (Loose)
121	127	Fine to Med. Sand
127	142	Fine to Med. Sand & Gravel (Loose)
142	155	Med. Coarse Gravel (Loose)
155	160	Med. Sand & Gravel (Loose)
160	170	Med. Coarse Gravel, Coarse Rock (Loose)
170	174	Fine to Med. Sand & Gravel
174	205	Brown Sandy Clay
205	212	Brown Yellow mixed
212	215	Shale

T.D. - 180'

20' Screen