

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

Feldt #1

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County <u>Gray</u>	Fraction <u>Center NW 1/4</u>	1/4	1/4	Section number <u>2</u>	T <u>27</u>	S <u>27</u>	R <u>E</u>	Range number <u>27</u>	
2. Distance and direction from nearest town or city:					3. Owner of well: <u>Leon & D.J. Feldt</u>					
Street address of well location if in city:					R.R. or street: <u>403 Campus Drive</u>					
4. Locate with "X" in section below:	Sketch map:				6. Bore hole dia. <u>28</u> in. Completion date <u>3-27-76</u>					
					Well depth <u>178</u> ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
5. Type and color of material					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
Surface					9. Casing: Material <u>Metal</u> Height: Above or below <input type="checkbox"/> Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <u>30</u> ft. PVC <u>30</u> lbs./ft. Dia. <u>16</u> in. to <u>178</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>178</u> ft. depth gage No. <u>179</u>					
Fine sand					10. Screen: Manufacturer's name <u>W. A. Brown & Johnson</u>					
Sandy clay					Type <u>#444444</u> Dia. <u>16</u> in. Slot/gauze <u>#44</u> 1/8 in. Length <u>120</u> ft. Set between <u>64</u> ft. and <u>178</u> ft. <u>64</u> ft. and <u>178</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>3/8</u> down					
Fine sand					11. Static water level: <u>82</u> ft. below land surface Date <u>2-20-76</u>					
Caleche clay					12. Pumping level below land surfaces: <u>105</u> ft. after <u>1</u> hrs. pumping <u>900</u> g.p.m. <u>112</u> ft. after <u>1</u> hrs. pumping <u>1200</u> g.p.m. Estimated maximum yield <u>1400</u> g.p.m.					
Sand and gravel					13. Water sample submitted: <u>NA</u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____					
Yellow clay with 20% fine sand mixed					14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade					
Fine sand with 35% clay mixed					15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.					
Sand and gravel					16. Nearest source of possible contamination: <u>NA</u> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type _____					
Yellow clay with rock layers					Well disinfected upon completion? <u>Yes</u> <input type="checkbox"/> No					
Blue shale					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>Goulds</u> Model number <u>12JMC</u> HP <u>80</u> Volts _____ Length of drop pipe <u>160</u> ft. capacity <u>800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Ace-Hi International</u> 190 Business name <u>Dodge City, Kansas</u> License No. _____ Address <u>Dodge City, Kansas</u> Signed <u>Leon Feldt</u> Date <u>4-3-76</u> Authorized representative _____					
18. Elevation:	19. Remarks: <u>Grouting and cement slab to be installed by customer</u> <u>Leon Feldt</u>									
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley										