


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name East Hess	Fraction N.W. $\frac{1}{4}$	Section number #8	Town number T #27 E S	Range number R #27 S W
Distance and direction from nearest town or city: and 3 miles east of 6 miles South			3 Owner of well: Russell Monical			
Street address of well location if in city: Cimarron, Kansas			Address: Cimarron, Kansas 67835			
Locate with "X" in section below: 			Sketch map: NW $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section #8 T #27 E and R #27 S			
4 Well depth:	185		ft. Date of completion	5-20-75		
Well diameter	8		in.			
5	<input type="checkbox"/> Cable tool	<input checked="" type="checkbox"/> Rotary	<input type="checkbox"/> Driven	<input type="checkbox"/> Dug		
	<input type="checkbox"/> Hollow rod	<input type="checkbox"/> Jetted	<input type="checkbox"/> Bored	<input type="checkbox"/> Reverse rotary		
6 Use:	<input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well					
7 Casing: Material	RMP		Height: above	12		
Threaded	<input type="checkbox"/>	Welded	<input type="checkbox"/>	Surface	12	in.
Diam.	5		Weight	185 lbs./ft.		
in. to	185 ft. depth		Drive shoe?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
in. to	185 ft. depth					
8 Screen:	Jess & Lowell					
Manufacturer	Jess & Lowell		Dia.	5"		
Type	RMP		5"			
Sieve/gauze	1/8"		Length	20ft.		
Set between	160 ft. and 180 ft.					
Fittings:						
Gravel pack	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	Size range of material 1"			
9 Static water level:	84 ft. below land surface Date 5-20-75					
10 Pumping level below land surfaces:	84 ft. after 2 hrs. pumping 50 g.p.m.					
	84 ft. after 2 hrs. pumping 50 g.p.m.					
Estimated maximum yield	150 g.p.m.					
11 Water sample submitted:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____					
12 Well head completion:	<input checked="" type="checkbox"/> Pitless adapter 12 inches above grade					
13 Well grouted?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No				
Neat cement	<input type="checkbox"/>	Bentonite				
Depth: From	10	ft. to 20 ft.				
14 Nearest source of possible contamination:	Sewer					
ft. 125 Direction SE Type _____						
Well disinfected upon completion?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No				
15 Pump:	<input type="checkbox"/> Not installed					
Manufacturer's name	Aermotor					
Model number	SD19100 1		Volts	230		
Length of drop pipe	126 ft.		capacity	19 g.m.p.		
Type:						
<input checked="" type="checkbox"/> Submersible	<input type="checkbox"/> Turbine					
<input type="checkbox"/> Jet	<input type="checkbox"/> Reciprocating					
<input type="checkbox"/> Centrifugal	<input type="checkbox"/> Other					
16 Remarks: elevation						
Topography:						
<input type="checkbox"/> Hill	<input type="checkbox"/> Turbine					
<input checked="" type="checkbox"/> Slope	<input type="checkbox"/> Reciprocating					
<input type="checkbox"/> Upland	<input type="checkbox"/> Other					
<input type="checkbox"/> Valley						
(use a second sheet if needed)						
17 Water well contractor's certification:						
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.						
JOE'S WELL SERVICE 179						
Business name	License No.					
Address	Box 179 Cimarron, Ks.					
Signed	Joe Clark Date 6-6-75					
Authorized representative						