

## WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL:	Fraction COUNTY: GRAY NE 1/4 NE 1/4 NE 1/4	Section Number 9	Township Number T 27 S	Range Number R 27 E
---------------------------	--	---------------------	---------------------------	------------------------

Distance and direction from nearest town or city street address of well if located within city?  
FROM CIMARRON - 6 MILES SOUTH AND 4 MILES EAST

2 WATER WELL OWNER:	CALHOUN, ROD RR#, St. Address, Box #:	Board of Agriculture, Division of Water Resources
City, State, ZIP code :	CIMARRON, KS 67835-	Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL 178 ELEVATION: 0 Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.																				
<table border="1"> <tr> <td>X</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1 NW</td> <td>NE</td> <td></td> <td></td> </tr> <tr> <td>M W</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1 SW</td> <td>SE</td> <td></td> <td></td> </tr> <tr> <td>\ /</td> <td></td> <td></td> <td></td> </tr> </table>	X				1 NW	NE			M W				1 SW	SE			\ /				<p>WELL'S STATIC WATER LEVEL 105 ft. below land surface measured on mo/day/yr 04/15/93 Pump testdata: Well water was 0 ft. after 0 hours pumping 0 gpm Estimated Yield 0 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm Bore Hole Diameter 8 in. to 178 ft., and in. to 0 ft.</p> <p>WELL WATER TO BE USED AS: DOMESTIC</p> <p>Was a chemical/bacteriological sample submitted to department? No ; If yes, mo/day/yr sample was submitted Water well disinfected? Yes</p>
X																					
1 NW	NE																				
M W																					
1 SW	SE																				
\ /																					

5 TYPE OF BLANK CASING USED: PVC	CASING JOINTS: GLUED
Blank casing diameter 5 in. to 178 ft., Dia in. to 0 ft., Dia in. to 0 ft.	Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21
TYPE OF SCREEN OR PERFORATION MATERIAL: PVC	SCREEN OR PERFORATION OPENINGS ARE: SAW CUT
SCREEN PERFORATED INTERVALS:	From 152 ft. to 172 ft., From 0 ft. to 0 ft. From 0 ft. to 0 ft., From 0 ft. to 0 ft.
GRAVEL PACK INTERVALS:	From 25 ft. to 178 ft., From 0 ft. to 0 ft. From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE	Grout Intervals: From 0 ft. to 25 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.
What is the nearest source of possible contamination: NONE - NEW SITE	Direction from well? How many feet? 0

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	20	TOPSOIL CLAY FINE SAND			
20	80	FINE SAND			
80	100	FINE - MED SAND COARSE SAND			
100	120	CLAY LAYERS FINE SAND			
120	160	FINE - MED SAND SMALL GRAVEL			
160	164	CLAY			
164	180	MED-COARSE SAND SMALL GRAVEL			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 04/16/93 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 04/27/93 under the business name of JOE'S WELL SERVICE, INC.	by (signature) <i>Joe's Well Service</i>
--	--