


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 SW 1/4 SE 1/4	Section number 11	Township number T 27 S	Range number R 27 E	
2. Distance and direction from nearest town or city:	Approximately 3 3/4 miles North of Ensign, Kansas.		3. Owner of well: R.R. or street: City, state, zip code:	Howard Beggs Ensign, Kansas 67841		
4. Locate with "X" in section below:	<p style="text-align: center;">Sketch map:</p> 		6. Bore hole dia. 26 in. Completion date Well depth 230 ft. 7/19/78			
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Steel Height (Above) below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.75 lbs./ft. Dia. 16 in. to 230 depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188			
5. Type and color of material	From	To	10. Screen: Manufacturer's name Johnson Screen Type Continuous Dia. 16" Slot/gauge .100 Length 40' Set between 140 ft. and 150 ft. 160 ft. and 190 ft. Gravel pack? Yes Size range of material. #1 Coarse			
See Attachment			11. Static water level: 144 ft. below land surface Date 7/21/78 mo./day/yr.			
			12. Pumping level below land surfaces: 308 220 ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. 250 ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 250 g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
			14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter			
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: <input type="checkbox"/> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)			18. Elevation: x Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Sply 145 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 639, Garden City, Ks. Signed Bruce J. Rechmuth Date 7/25/78 Authorized representative <input type="checkbox"/>			

DRILLERS TEST LOG

CUSTOMERS NAME Howard Beggs DATE 4/17/78
STREET ADDRESS _____ TEST # 24 E. LOG Yes
CITY & STATE Ensign, Kansas DRILLER Martinez
COUNTY Gray QUARTER SE SECTION 11 TOWNSHIP 27 RANGE 27

LOCATION _____

GARDEN CITY, KS
Phone 276-3278
TEST HOLES * * *

HENKLE DRILLING & SUPPLY CO., INC.
IRRIGATION HEADQUARTERS
*IRRIGATION & INDUSTRIAL WELLS * *

SUBLETTE, KS
Phone 675-4311
* * STOCK WELLS