



USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction <input checked="" type="checkbox"/> NE 1/4	Section number 14	Township number T 27	Range number S R 27	EW
2. Distance and direction from nearest town or city: 6 1/4 S. and 5 3/4 E. of Cimarron Street address of well location if in city:	3. Owner of well: E. V. Bryan R.R. or street: Cimarron, KS 67835					
4. Locate with "X" in section below:    Sketch map:  Well drilled 3-4-76	6. Bore hole dia. 26 in. Completion date 3-5-76 Well depth 206 ft.					
	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42 lbs./ft. Dia 16 in. to 206 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .250					
5. Type and color of material  See attachment	From	To	10. Screen: Manufacturer's name Johnson  Type Continuous Dia. 16" Slot/gauze .100 Length 30' Set between 160 ft. and 190 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4 x 1/8			
			11. Static water level: mo./day/yr. 130 ft. below land surface Date 3-5-76			
			12. Pumping level below land surfaces: 190 ft. after <input type="checkbox"/> hrs. pumping 1,014 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.			
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Observed Well disinfected upon completion? Yes <input type="checkbox"/> No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)			18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			
19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling and Supply 145 Business name <input type="checkbox"/> License No. Address Box 639, Garden City, KS Signed  Date 3-26-76 Authorized representative			

## DRILLERS TEST LOG

CUSTOMERS NAME E. V. Bryan DATE 2-16-76  
 STREET ADDRESS  TEST #1 E. Log 220 Ft.  
 CITY & STATE Cimarron, Kansas DRILLER Rector  
 COUNTY Gray QUARTER NE SECTION 14 TOWNSHIP 27 RANGE 27  
 LOCATION in Center of 1/4 and 20 Ft. East of Pivot  
Samples in on this test.

## POSSIBLE WELL LOCATION.

%	FOOTAGE			STATIC WATER LEVEL
	DRILLED FROM	PAY	TO	PROPOSED WELL DEPTH
	0		2	Top soil
	3		80	Brown sandy clay and few sand st.
	80		95	Sand fine med. coarse, small coarse, few small clay st.
	95		120	Sand fine med. coarse, some med. gravel. Fairly loose. Used water.
70	120	30	160	Sand and gravel fine med. coarse, small and some large. Loose. Used lots of water.
75	160	43	203	Sand fine med. coarse, med. to small gravel. Few, small white rock. Real loose. Used lots of water. VEry good.
	203		216	Brown sandy clay and fine sand
	216		218	Soapstone and some yellow clay
	218		220	Shale
	73			Total Depth of Well 206 Ft.

Set up facing NORTH  
Pit on the east.

HENKLE DRILLING &amp; SUPPLY CO., INC.

GARDEN CITY, KANSAS  
Phone 276-3278

TEST HOLES DOMESTIC WELLS STOCK WELLS IRRIGATION & INDUSTRIAL WELLS

SUBLETTE, KANSAS  
Phone 675-4434