



USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> SE 1/4	Center of Section number 14	Township number T 27	Range number (S) R 27 E (W)		
2. Distance and direction from nearest town or city: 7 S. and 5 3/4 E. of Cimarron Street address of well location if in city:	3. Owner of well: E. V. Bryan R.R. or street: City, state, zip code: Cimarron, KS						
4. Locate with "X" in section below:  	Sketch map:  Well drilled 3-3-76						
5. Type and color of material  See attachment	From	To	6. Bore hole dia. 26 in. Completion date 3-8-76 Well depth 233 ft.				
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary				
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
			9. Casing: Material <input checked="" type="checkbox"/> Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42 lbs./ft. Dia 16 in. to 233 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250				
			10. Screen: Manufacturer's name Johnson Type Continuous Dia. 16" Slot/gauze .100 Length 30' Set between 160 ft. and 170 ft. 195 ft. and 215 ft. Gravel pack? Yes Size range of material $\frac{1}{4}$ x 1/8				
			11. Static water level: mo./day/yr. 136 ft. below land surface Date 3-8-76				
			12. Pumping level below land surfaces: 188 ft. after hrs. pumping 1,151 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.				
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date				
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade				
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				
			16. Nearest source of possible contamination: None ft. Direction Type observed Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No				
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
(Use a second sheet if needed)			18. Elevation: 19. Remarks:  Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. Address Box 639 Garden City, KS Signed  Authorized representative Date 3/31/76				

## DRILLERS TEST LOG

CUSTOMERS NAME E. V. Bryan DATE 2-14-76  
 STREET ADDRESS South TEST # 2 E. Log 240  
 CITY & STATE Cimarron, Kansas DRILLER Rector  
 COUNTY Gray QUARTER SE SECTION 14 TOWNSHIP 27 RANGE 27  
 LOCATION 1320 Ft. South and a little west of Test # 1 & 20 Ft. E. of  
Pivot. Samples in on this test.

S.	DRILLED		FOOTAGE TO	STATIC WATER LEVEL
	FROM	PAY		PROPOSED WELL DEPTH
	0		3	Top soil
	3		20	Brown sandy clay
	20		47	Brown clay
	47		60	Brown sandy clay and sand
	60		87	Sand fine med. coarse, small coarse.
	87		93	Brown clay
	93		118	Sand fine med. coarse, few med. small gravel, Fairly loose. Used water
	118		120	Clay st.
70	120	30	160	Sand fine med. coarse, small gravel. Some large. Used lots of water. Very Good.
65	160	9	169	Sand fine med. coarse, small gravel. Real loose. Used lots of water.
35	169	3	172	Coarse sand and sandy clay
	172		184	Brown clay and caliche
75	184	34	218	Sand fine med. coarse, small gravel. Few, white rock, loose. Used lots of water. Very Good
	218		220	Brown sandy clay
70	220	11	231	Sand fine med. coarse, small gravel and smaller white rock. Real loose, Used lots of water.
	231		232	Brown clay
	232		240	Shale
	87			TOTAL DEPTH OF WELL 233 FT.
				Set up facing North
				Pit on the east.

HENKLE DRILLING &amp; SUPPLY CO., INC.

GARDEN CITY, KANSAS  
Phone 276-3278

TEST HOLES DOMESTIC WELLS STOCK WELLS IRRIGATION &amp; INDUSTRIAL

SUBLETTE, KANSAS  
Phone 675-4311