

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 17	Township number T 27 S	Range number R 27 E (W)
2. Distance and direction from nearest town or city: 7 S. & 2 1/2 E. of Cimarron Street address of well location if in city:			3. Owner of well: Virgil Salem R.R. or street: City, state, zip code: Cimarron, KS 67835		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:			6. Bore hole dia. 26 in. Completion date 10-14-76 Well depth 207 ft.		
5. Type and color of material See attachment From To			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 207 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
			10. Screen: Manufacturer's name Johnson Type Continuous Dia. 16 " Slot/gauze .080 Length 30 ' Set between 185 ft. and 155 ft. Gravel pack? yes Size range of material 1/4 x 1/8		
			11. Static water level: 128 ft. below land surface Date 10-14-76 mo./day/yr.		
			12. Pumping level below land surfaces: 151 ft. after <input type="checkbox"/> hrs. pumping 797 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: None Observed ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name License No. Address Box 639, Garden City, KS Signed E.L. Bothwell Date 10-26-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Virgil Salem DATE 9-29-76
STREET ADDRESS _____ TEST # 4 E. Log 220'
CITY & STATE Cimarron, KS DRILLER Rector
COUNTY Gray QUARTER SW SECTION 17 TOWNSHIP 27 RANGE 27

LOCATION NW corner of 1/4

WELL LOCATION

[illegible]

GARDEN CITY, KANSAS	HENKLE DRILLING & SUPPLY CO., INC.	SUBLETTE, KANSAS
PHONE 276-3278	IRRIGATION HEADQUARTERS	PHONE 675-4311

TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****