


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE 1/4 SW 1/4 NE 1/4	Section number 22	Township number T 27	Range number S R 27 E/W
2. Distance and direction from nearest town or city: Cimarron, Ks., 4 3/4 east, 1/4 south	3. Owner of well: Walter Redger R.R. or street: City, state, zip code: Montezuma, Ks. 678				
4. Locate with "X" in section below: 	Sketch map:				
6. Bore hole dia. 26 in. Completion date 8-1-75 Well depth 240 ft.					
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other Steel					
9. Casing: Material <input type="checkbox"/> Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 241 ft. depth! Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>					
10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/ gape <input type="checkbox"/> Length 20' Set between 210 ft. and 230 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <input type="checkbox"/> down					
11. Static water level: 135 ft. below land surface Date 8-9-75 mo./day/yr.					
12. Pumping level below land surfaces: 152 ft. after 2 hrs. pumping 708 g.p.m. 159 ft. after 4 hrs. pumping 1000 g.p.m. Estimated maximum yield 1000 g.p.m.					
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>					
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade					
15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>					
17. Pump: Not installed Manufacturer's name Peerless - FMC Model number 97345 HP 100 Volts <input type="checkbox"/> Length of drop pipe 180 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	<p>20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name Address Signature: <i>Michael D. Wilson</i> Date 10-17-75 Authorized representative</p>				

KELLY-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 755-2111 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Art Scroggins
Walter Redger (tenant)
Gray County
7-21-75

Location: 250 ft. east of Pivot point NE^{1/4} 22-27-27

Test #2

0	4	Top soil
4	32	Brown sandy clay
32	97	Fine to med. sand
97	135	Fine to med. sand (tight)
135	139	Fine to med. sand & gravel (tight)
139	180	Fine to med. sand & gravel (loose)
180	204	Brown sandy clay
204	240	Fine to med. sand & gravel (good)
240	243	Gray clay
243	245	Shale

Static Water Level: 130

T.D. 240