


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 6620

1. Location of well:	County Gray	Fraction SW 1/4 SE 1/4 SE 1/4	Section number 34	Township number T 27 S R 27 E NW	Range number		
2. Distance and direction from nearest town or city: 1 mi. W of Ensign Street address of well location if in city:	3. Owner of well: Steve Sayre Ensign, KS 67841						
4. Locate with "X" in section below: 	Sketch map:	6. Bore hole dia. 26 in. Completion date 1-3-77 Well depth 309 ft.					
5. Type and color of material See attachment	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary				
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. 309 ft. depth! Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth! gage No. .250				
			10. Screen: Manufacturer's name Johnson Type Continuous dia. 16" Slot/gauze .100 Length 70' Set between 279 ft. and 209 ft. ft. and ft. Gravel pack? Yes Size range of material 1/4 x 1/8				
			11. Static water level: 166 ft. below land surface Date 1-6-77 mo./day/yr.				
			12. Pumping level below land surfaces: 195 ft. after <input type="checkbox"/> hrs. pumping 1550 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.				
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>				
			14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter <input type="checkbox"/>				
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. None ft. observed Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				
			16. Nearest source of possible contamination: <input type="checkbox"/> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
(Use a second sheet if needed)		18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				19. Remarks:	
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilg. & Supply 145 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 639 Garden City, KS Signed E. L. Borthwell Date 1-27-77 Authorized representative <input type="checkbox"/>	

DRILLERS TEST LOG

CUSTOMERS NAME	Steve Sayre	DATE	12-21-76						
STREET ADDRESS		TEST #	1 E. Log						
CITY & STATE	Ensign, KS	DRILLER	Lee						
COUNTY	Gray	QUARTER	SE	SECTION	34	TOWNSHIP	27	RANGE	27

LOCATION 820' W and 100' N of the SE corner of the SE 1/4. Old test
20' E drilled by Ace High Drilling Co.

GARDEN CITY, KANSAS
PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
PHONE 675-4311

TEST HOLES***** STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****