



USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 2	Township number T 27	Range number S R 28	
2. Distance and direction from nearest town or city: 1/2 mile west of Ensign, Kansas	3. Owner of well: R.R. or street: City, state, zip code:		Leon Feldt Dodge City, Howell, Kansas 67801			
Street address of well location if in city:						
4. Locate with "X" in section below: 		Sketch map:				
5. Type and color of material		From	To	6. Bore hole dia. 97/8 in. Completion date _____ Well depth 167 ft. 3-30-77		
Fine sand		0	7	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Sandy clay		7	60	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Med. to lar. sand & gravel		60	158	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 167 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 265		
Black shale		158	170	10. Screen: Manufacturer's name Jess & Lowell Type PVC Dia. 5" 1/8" Length 50' Slot/gauge Set between 117 ft. and 167 ft. ft. and ft. Gravel pack? Yes Size range of material #1 fine		
				11. Static water level: mo./day/yr. 73 ft. below land surface Date 3/4/77		
				12. Pumping level below land surfaces: ft. after _____ hrs. pumping _____ g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: Pitless adapter 12 Inches above grade		
				15. Well grouted? Yes by customer With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: None ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name Rebuilt tower & mill Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity 2 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other		
		(Use a second sheet if needed)		18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
				19. Remarks:		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name Meade, Kansas 67864 License No. Address _____ Signed  Authorized representative Date 4-3-77		